

CATEGORY:

**IC ENGINE COMPRESSION-STANDBY**

BACT Size: Minor Source BACT

**IC ENGINE STANDBY**

<b>BACT Determination Number:</b> 116	<b>BACT Determination Date:</b> 2/11/2016
---------------------------------------	---

**Equipment Information**

**Permit Number:** 24758  
**Equipment Description:** IC ENGINE STANDBY  
**Unit Size/Rating/Capacity:** I.C. Engine, Standby, Diesel-fueled >=50 HP  
**Equipment Location:** PHILLIPS 66 COMPANY  
 76 BROADWAY  
 SACRAMENTO, CA

**BACT Determination Information**

<b>ROCs</b>	<b>Standard:</b>	Applicable NMHC + NOx Tier Standard
	<b>Technology Description:</b>	Applicable NMHC + NOx emission standard for horsepower range based on the ATCM for Stationary CI Engines
	<b>Basis:</b>	Achieved in Practice
<b>NOx</b>	<b>Standard:</b>	Applicable NMHC + NOx Tier Standard
	<b>Technology Description:</b>	Applicable NMHC + NOx emission standard for horsepower range based on the ATCM for Stationary CI Engines
	<b>Basis:</b>	Achieved in Practice
<b>SOx</b>	<b>Standard:</b>	CARB Diesel
	<b>Technology Description:</b>	Diesel fuel with a sulfur content no greater than 0.0015% by weight
	<b>Basis:</b>	Achieved in Practice
<b>PM10</b>	<b>Standard:</b>	Applicable PM Tier Standard
	<b>Technology Description:</b>	Applicable PM emission standard for horsepower range based on the ATCM for Stationary CI Engines
	<b>Basis:</b>	Achieved in Practice
<b>PM2.5</b>	<b>Standard:</b>	Applicable PM Tier Standard
	<b>Technology Description:</b>	Applicable PM emission standard for horsepower range based on the ATCM for Stationary CI Engines
	<b>Basis:</b>	Achieved in Practice
<b>CO</b>	<b>Standard:</b>	Applicable CO Tier Standard
	<b>Technology Description:</b>	Applicable CO emission standard for horsepower range based the ATCM for Stationary CI Engines
	<b>Basis:</b>	Achieved in Practice
<b>LEAD</b>	<b>Standard:</b>	
	<b>Technology Description:</b>	
	<b>Basis:</b>	

**Comments:** For emergency engines 50 ≤ bhp < 75, Tier 4 Interim certification is the requirement; for emergency engines 75 ≤ bhp < 750, Tier 3 certification is the requirement; for emergency engines ≥ 750 bhp, Tier 2 certification is the requirement.

**District Contact:** Isam Boulad Phone No.: (916) 874 - 4859 email: [iboulad@airquality.org](mailto:iboulad@airquality.org)



**BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION**

**DETERMINATION NO.:** 116  
**DATE:** Jan 14, 2016  
**ENGINEER:** Matt Baldwin

**Category/General Equip Description:** Internal Combustion (I.C.) Engine  
**Equipment Specific Description:** I.C. Engine, Standby, Diesel-fueled  
**Equipment Size/Rating:** Minor Source BACT  
**Previous BACT Det. No.:** No. 111

This BACT determination will update the following determinations:

#111 which was made on August 13, 2015 for diesel standby I.C. engines BHP ≥ 50

This BACT determination is being updated to include direct-drive fire pump engines, which are subject to different emissions standards pursuant to state and federal regulations. Additionally, this determination is being updated to include T-BACT for diesel particulate matter (diesel PM).

**BACT/T-BACT ANALYSIS**

**A. ACHIEVED IN PRACTICE (Rule 202, §205.1a):**

The following control technologies are currently employed as BACT/T-BACT for diesel-fueled standby engines by the following agencies and air pollution control districts:

Note: Diesel PM is the primary driver for health risks associated with diesel engines. Diesel PM is emitted as PM10 and PM2.5, and the same control technologies that control PM10 and PM2.5 also control diesel PM.

District/Agency	Best Available Control Technology (BACT)/Requirements
US EPA	<b>BACT</b> <a href="#">Source: EPA RACT/BACT/LAER Clearinghouse</a>
	For standby units with a rating of 50 ≤ BHP < 175
	VOC   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
	NOx   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
	SOx   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
	PM10   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
	PM2.5   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
	CO   N/A – No BACT determinations found in the 50 ≤ BHP < 175 range
<b>RBLC ID:</b> N/A	

District/Agency	Best Available Control Technology (BACT)/Requirements
US EPA (continued)	For standby units with a rating of $175 \leq \text{BHP} < 750$
	VOC 4.0 g/KW-hr (3.0 g/hp-hr) NMHC + NOx; Emission Standards based on 40 CFR Part 60, Subpart IIII
	NOx 4.0 g/KW-hr (3.0 g/hp-hr) NMHC + NOx; Emission Standards based on 40 CFR Part 60, Subpart IIII
	SOx Diesel fuel with a sulfur content no greater than 0.0015% by weight
	PM10 0.20 g/KW-hr (0.15 g/hp-hr) PM10 (filterable); Emission Standards based on 40 CFR Part 60, Subpart IIII
	PM2.5 0.20 g/KW-hr (0.15 g/hp-hr) PM2.5 (filterable); Emission Standards based on 40 CFR Part 60, Subpart IIII
	CO 3.5 g/KW-hr (2.6 g/hp-hr) CO; Emission Standards based on 40 CFR Part 60, Subpart IIII
	<b>RBLC ID:</b> See Attachment A
	For standby units with a rating of $\text{BHP} \geq 750$
	VOC 6.4 g/KW-hr (4.8 g/hp-hr) NMHC + NOx; Emission Standards based on 40 CFR Part 60, Subpart IIII
	NOx 6.4 g/KW-hr (4.8 g/hp-hr) NMHC + NOx; Emission Standards based on 40 CFR Part 60, Subpart IIII
	SOx Diesel fuel with a sulfur content no greater than 0.0015% by weight
	PM10 0.20 g/KW-hr (0.15 g/hp-hr) PM10 (filterable); Emission Standards based on 40 CFR Part 60, Subpart IIII
	PM2.5 0.20 g/KW-hr (0.15 g/hp-hr) PM2.5 (filterable); Emission Standards based on 40 CFR Part 60, Subpart IIII
	CO 3.5 g/KW-hr (2.6 g/hp-hr) CO; Emission Standards based on 40 CFR Part 60, Subpart IIII
	<b>RBLC ID:</b> See Attachment A
	<b>T-BACT</b>
	There are no T-BACT standards published in the clearinghouse for this category.
	<b>RULE REQUIREMENTS:</b>
	<a href="#">40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Internal Combustion Engines</a> : This regulation applies to owners/operators of new stationary compression ignition engines that commenced construction after July 11, 2005. [40 CFR §60.4200]
	<u>40 CFR §60.4205(b)</u>
	Owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in §60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.
	<u>40 CFR §60.4205(c)</u>
	Owners and operators of fire pump engines with a displacement of less than 30 liters per cylinder must comply with the emission standards in table 4 to this subpart, for all pollutants.

District/Agency	Best Available Control Technology (BACT)/Requirements																																																
US EPA (continued)	<p>Note: The emission standards listed in Table 4 of Subpart IIII are the same as those listed in the Table below, except that fire pumps were given an additional three years to comply with those standards. As the date of this determination, new emergency use fire pumps are subject to the same emissions standards as emergency use non-fire pumps.</p>																																																
	<p><u>40 CFR §60.4202(a)(2)</u>  For engines with a maximum engine power greater than or equal to 37 KW (50 HP), the certification emission standards for new nonroad CI engines for the same model year and maximum engine power in 40 CFR 89.112 (emission standards) and 40 CFR 89.113 (smoke standards) for all pollutants beginning in model year 2007.</p>																																																
	<table border="1"> <thead> <tr> <th colspan="6" data-bbox="424 757 1388 786">40 CFR §89.112 Table 1: Emission Standards in g/kW-hr (g/hp-hr)</th> </tr> <tr> <th data-bbox="424 786 624 846">Maximum engine power</th> <th data-bbox="624 786 746 846">Tier</th> <th data-bbox="746 786 876 846">Model year(s)</th> <th data-bbox="876 786 1050 846">PM</th> <th data-bbox="1050 786 1225 846">NMHC + NOx</th> <th data-bbox="1225 786 1388 846">CO</th> </tr> </thead> <tbody> <tr> <td data-bbox="424 846 624 907">37≤kW&lt;75 (50≤hp&lt;100)</td> <td data-bbox="624 846 746 907">3</td> <td data-bbox="746 846 876 907">2008+</td> <td data-bbox="876 846 1050 907">0.40 (0.30)</td> <td data-bbox="1050 846 1225 907">4.7 (3.5)</td> <td data-bbox="1225 846 1388 907">5.0 (3.7)</td> </tr> <tr> <td data-bbox="424 907 624 967">75≤kW&lt;130 (100≤hp&lt;175)</td> <td data-bbox="624 907 746 967">3</td> <td data-bbox="746 907 876 967">2007+</td> <td data-bbox="876 907 1050 967">0.30 (0.22)</td> <td data-bbox="1050 907 1225 967">4.0 (3.0)</td> <td data-bbox="1225 907 1388 967">5.0 (3.7)</td> </tr> <tr> <td data-bbox="424 967 624 1028">130≤kW&lt;225 (175≤hp&lt;300)</td> <td data-bbox="624 967 746 1028">3</td> <td data-bbox="746 967 876 1028">2006+</td> <td data-bbox="876 967 1050 1028">0.20 (0.15)</td> <td data-bbox="1050 967 1225 1028">4.0 (3.0)</td> <td data-bbox="1225 967 1388 1028">3.5 (2.6)</td> </tr> <tr> <td data-bbox="424 1028 624 1088">225≤kW&lt;450 (300≤hp&lt;600)</td> <td data-bbox="624 1028 746 1088">3</td> <td data-bbox="746 1028 876 1088">2006+</td> <td data-bbox="876 1028 1050 1088">0.20 (0.15)</td> <td data-bbox="1050 1028 1225 1088">4.0 (3.0)</td> <td data-bbox="1225 1028 1388 1088">3.5 (2.6)</td> </tr> <tr> <td data-bbox="424 1088 624 1149">450≤kW&lt;560 (600≤hp&lt;750)</td> <td data-bbox="624 1088 746 1149">3</td> <td data-bbox="746 1088 876 1149">2006+</td> <td data-bbox="876 1088 1050 1149">0.20 (0.15)</td> <td data-bbox="1050 1088 1225 1149">4.0 (3.0)</td> <td data-bbox="1225 1088 1388 1149">3.5 (2.6)</td> </tr> <tr> <td data-bbox="424 1149 624 1211">kW&gt;560 (hp&gt;750)</td> <td data-bbox="624 1149 746 1211">2</td> <td data-bbox="746 1149 876 1211">2006+</td> <td data-bbox="876 1149 1050 1211">0.20 (0.15)</td> <td data-bbox="1050 1149 1225 1211">6.4 (4.8)</td> <td data-bbox="1225 1149 1388 1211">3.5 (2.6)</td> </tr> </tbody> </table>	40 CFR §89.112 Table 1: Emission Standards in g/kW-hr (g/hp-hr)						Maximum engine power	Tier	Model year(s)	PM	NMHC + NOx	CO	37≤kW<75 (50≤hp<100)	3	2008+	0.40 (0.30)	4.7 (3.5)	5.0 (3.7)	75≤kW<130 (100≤hp<175)	3	2007+	0.30 (0.22)	4.0 (3.0)	5.0 (3.7)	130≤kW<225 (175≤hp<300)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)	225≤kW<450 (300≤hp<600)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)	450≤kW<560 (600≤hp<750)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)	kW>560 (hp>750)	2	2006+	0.20 (0.15)	6.4 (4.8)	3.5 (2.6)
	40 CFR §89.112 Table 1: Emission Standards in g/kW-hr (g/hp-hr)																																																
	Maximum engine power	Tier	Model year(s)	PM	NMHC + NOx	CO																																											
	37≤kW<75 (50≤hp<100)	3	2008+	0.40 (0.30)	4.7 (3.5)	5.0 (3.7)																																											
	75≤kW<130 (100≤hp<175)	3	2007+	0.30 (0.22)	4.0 (3.0)	5.0 (3.7)																																											
130≤kW<225 (175≤hp<300)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)																																												
225≤kW<450 (300≤hp<600)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)																																												
450≤kW<560 (600≤hp<750)	3	2006+	0.20 (0.15)	4.0 (3.0)	3.5 (2.6)																																												
kW>560 (hp>750)	2	2006+	0.20 (0.15)	6.4 (4.8)	3.5 (2.6)																																												
<p><a href="#">40 CFR Part 63 Subpart ZZZZ – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines</a>: This regulation applies to new and existing stationary IC engines. New emergency engines that comply with 40 CFR 60 Subpart IIII already meet the requirements of this NESHAP, as noted below.</p>																																																	
<p><u>40 CFR §63.6590(c)</u>  <i>Stationary RICE subject to Regulations under 40 CFR Part 60.</i> An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.</p>																																																	

District/Agency	Best Available Control Technology (BACT)/Requirements																												
Air Resources Board (ARB)	<p><b>BACT</b>  <a href="#">Source: ARB BACT Clearinghouse</a></p> <table border="1" data-bbox="427 510 1399 728"> <thead> <tr> <th colspan="2">For standby units with a rating of BHP &lt; 175</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the BHP &lt; 175 range</td> </tr> </tbody> </table> <table border="1" data-bbox="427 757 1399 974"> <thead> <tr> <th colspan="2">For standby units with a rating of BHP ≥ 175</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the BHP ≥ 175 range</td> </tr> </tbody> </table> <p>Note: As of the date of this determination, the ARB BACT Clearinghouse has three listings for engines ≥ 175 BHP. All three were for prime-use engines and therefore deemed not applicable.</p> <p><b>T-BACT</b>            There are no T-BACT standards published in the clearinghouse for this category.</p> <p><b>RULE REQUIREMENTS:</b>  <a href="#">Title 17, Cal. Code Regs. Sections 93115 through 93115.15 – Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition (CI) Engines:</a> This regulation applies to owners/operators of new and existing stationary compression ignition engines greater than 50 bhp.</p> <p>§93115.6(a): New Emergency Standby Diesel-Fueled CI Engine Emission Standards.            (1) At-School and Near-School Provisions. No owner or operator shall operate a new stationary emergency standby diesel-fueled CI engine for non-emergency use, including maintenance and testing, during the following periods:            (A) whenever there is a school sponsored activity, if the engine is located on school grounds, and            (B) between 7:30 a.m. and 3:30 p.m. on days when school is in session, if the engine is located within 500 feet of school grounds. Section 93115.6(a)(1) does not apply if the engine emits no more than 0.01 g/bhp-hr of diesel PM.</p>	For standby units with a rating of BHP < 175		VOC	N/A – No BACT determinations found in the BHP < 175 range	NOx	N/A – No BACT determinations found in the BHP < 175 range	SOx	N/A – No BACT determinations found in the BHP < 175 range	PM10	N/A – No BACT determinations found in the BHP < 175 range	PM2.5	N/A – No BACT determinations found in the BHP < 175 range	CO	N/A – No BACT determinations found in the BHP < 175 range	For standby units with a rating of BHP ≥ 175		VOC	N/A – No BACT determinations found in the BHP ≥ 175 range	NOx	N/A – No BACT determinations found in the BHP ≥ 175 range	SOx	N/A – No BACT determinations found in the BHP ≥ 175 range	PM10	N/A – No BACT determinations found in the BHP ≥ 175 range	PM2.5	N/A – No BACT determinations found in the BHP ≥ 175 range	CO	N/A – No BACT determinations found in the BHP ≥ 175 range
	For standby units with a rating of BHP < 175																												
	VOC	N/A – No BACT determinations found in the BHP < 175 range																											
	NOx	N/A – No BACT determinations found in the BHP < 175 range																											
	SOx	N/A – No BACT determinations found in the BHP < 175 range																											
	PM10	N/A – No BACT determinations found in the BHP < 175 range																											
	PM2.5	N/A – No BACT determinations found in the BHP < 175 range																											
	CO	N/A – No BACT determinations found in the BHP < 175 range																											
	For standby units with a rating of BHP ≥ 175																												
	VOC	N/A – No BACT determinations found in the BHP ≥ 175 range																											
	NOx	N/A – No BACT determinations found in the BHP ≥ 175 range																											
	SOx	N/A – No BACT determinations found in the BHP ≥ 175 range																											
	PM10	N/A – No BACT determinations found in the BHP ≥ 175 range																											
	PM2.5	N/A – No BACT determinations found in the BHP ≥ 175 range																											
	CO	N/A – No BACT determinations found in the BHP ≥ 175 range																											

District/Agency	Best Available Control Technology (BACT)/Requirements																																																										
ARB (continued)	<p>(3) New Engines: As of January 1, 2005, except as provided in section 93115.3, no person shall sell, offer for sale, purchase, or lease for use in California any new stationary emergency standby diesel-fueled CI engine that has a rated brake horsepower greater than 50 unless it meets the following applicable emission standards, and no person shall operate any new stationary emergency standby diesel-fueled CI engine that has a rated brake horsepower greater than 50, unless it meets all of the following applicable operating requirements and emission standards specified in 93115.6(a)(3).</p> <p>(A) Emissions Standards and Hours of Operating Requirements.</p> <p>1. New stationary emergency standby diesel-fueled engines (&gt;50 bhp) shall:</p> <p>a. meet the applicable emission standards for all pollutants for the same model year and maximum horsepower rating as specified in Table 1 Emission Standards for New Stationary Emergency Standby Diesel-Fueled CI Engines, in effect on the date of acquisition or submittal, as defined in section 93115.4, and</p> <p>b. after December 31, 2008, be certified to the new nonroad compression-ignition (CI) engine emission standards for all pollutants for 2007 and later model year engines as specified in 40 CFR, Part 60, Subpart III-Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (2006);</p>																																																										
	<p style="text-align: center;">Table 1: Emission Standards for New Stationary Emergency Standby Diesel-Fueled CI Engines – g/bhp-hr (g/kW-hr)</p> <table border="1" data-bbox="426 1077 1388 1630"> <thead> <tr> <th>Maximum engine power</th> <th>Tier</th> <th>Model year(s)</th> <th>PM</th> <th>NMHC + NOx</th> <th>CO</th> </tr> </thead> <tbody> <tr> <td rowspan="2">50≤HP&lt;75 (37≤kW&lt;56)</td> <td>2</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td>5.6 (7.5)</td> <td rowspan="2">3.7 (5.0)</td> </tr> <tr> <td>4i</td> <td>2008+</td> <td>3.5 (4.7)</td> </tr> <tr> <td rowspan="2">75≤HP&lt;100 (56≤kW&lt;75)</td> <td>2</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td>5.6 (7.5)</td> <td rowspan="2">3.7 (5.0)</td> </tr> <tr> <td>3</td> <td>2008+</td> <td>3.5 (4.7)</td> </tr> <tr> <td rowspan="2">100≤HP&lt;175 (130≤kW&lt;225)</td> <td rowspan="2">3</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td rowspan="2">3.0 (4.0)</td> <td rowspan="2">3.7 (5.0)</td> </tr> <tr> <td>2008+</td> </tr> <tr> <td rowspan="2">175≤HP&lt;300 (130≤kW&lt;225)</td> <td rowspan="2">3</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td rowspan="2">3.0 (4.0)</td> <td rowspan="2">2.6 (3.5)</td> </tr> <tr> <td>2008+</td> </tr> <tr> <td rowspan="2">300≤HP&lt;600 (225≤kW&lt;450)</td> <td rowspan="2">3</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td rowspan="2">3.0 (4.0)</td> <td rowspan="2">2.6 (3.5)</td> </tr> <tr> <td>2008+</td> </tr> <tr> <td rowspan="2">600≤HP&lt;750 (450≤kW&lt;560)</td> <td rowspan="2">3</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td rowspan="2">3.0 (4.0)</td> <td rowspan="2">2.6 (3.5)</td> </tr> <tr> <td>2008+</td> </tr> <tr> <td rowspan="2">HP&gt;750 (kW&gt;560)</td> <td rowspan="2">2</td> <td>2007</td> <td rowspan="2">0.15 (0.20)</td> <td rowspan="2">4.8 (6.4)</td> <td rowspan="2">2.6 (3.5)</td> </tr> <tr> <td>2008+</td> </tr> </tbody> </table>	Maximum engine power	Tier	Model year(s)	PM	NMHC + NOx	CO	50≤HP<75 (37≤kW<56)	2	2007	0.15 (0.20)	5.6 (7.5)	3.7 (5.0)	4i	2008+	3.5 (4.7)	75≤HP<100 (56≤kW<75)	2	2007	0.15 (0.20)	5.6 (7.5)	3.7 (5.0)	3	2008+	3.5 (4.7)	100≤HP<175 (130≤kW<225)	3	2007	0.15 (0.20)	3.0 (4.0)	3.7 (5.0)	2008+	175≤HP<300 (130≤kW<225)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)	2008+	300≤HP<600 (225≤kW<450)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)	2008+	600≤HP<750 (450≤kW<560)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)	2008+	HP>750 (kW>560)	2	2007	0.15 (0.20)	4.8 (6.4)	2.6 (3.5)
Maximum engine power	Tier	Model year(s)	PM	NMHC + NOx	CO																																																						
50≤HP<75 (37≤kW<56)	2	2007	0.15 (0.20)	5.6 (7.5)	3.7 (5.0)																																																						
	4i	2008+		3.5 (4.7)																																																							
75≤HP<100 (56≤kW<75)	2	2007	0.15 (0.20)	5.6 (7.5)	3.7 (5.0)																																																						
	3	2008+		3.5 (4.7)																																																							
100≤HP<175 (130≤kW<225)	3	2007	0.15 (0.20)	3.0 (4.0)	3.7 (5.0)																																																						
		2008+																																																									
175≤HP<300 (130≤kW<225)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)																																																						
		2008+																																																									
300≤HP<600 (225≤kW<450)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)																																																						
		2008+																																																									
600≤HP<750 (450≤kW<560)	3	2007	0.15 (0.20)	3.0 (4.0)	2.6 (3.5)																																																						
		2008+																																																									
HP>750 (kW>560)	2	2007	0.15 (0.20)	4.8 (6.4)	2.6 (3.5)																																																						
		2008+																																																									

District/Agency	Best Available Control Technology (BACT)/Requirements																																																									
ARB (continued)	<p>(4) New Direct-Drive Emergency Standby Fire Pump Engines: Except as provided in section 93115.3, no person shall sell, offer for sale, purchase, or lease for use in California any new stationary emergency standby diesel-fueled direct-drive fire-pump CI engine that has a rated brake horsepower greater than 50 unless the fire-pump engine meets the applicable emission standards and certification requirements specified in section 93115.6(a)(4), and no person shall operate any new stationary emergency standby diesel-fueled direct-drive fire pump CI engine that has a rated brake horsepower greater than 50, unless it meets all of the applicable operating requirements and emission standards specified in 93115.6(a)(4).</p> <p>(A) Standards and Hours of Operating Requirements.</p> <p>1. New direct-drive emergency standby diesel-fueled fire-pump engines (&gt;50 bhp) shall:</p> <p>a. meet the applicable emissions standards for all pollutants as specified in Table 2 Emissions Standards for New Stationary Emergency Standby Direct-Drive Fire Pump Engines for the model year and NFPA nameplate power rating; and</p> <p>b. meet the new fire pump engine certification requirements and emission standards required by 40 CFR § 60.4202(d.) Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (2006); and</p> <p>c. not operate more than the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems," 2002 edition, which is incorporated herein by reference. This subsection does not limit engine operation for emergency use and for emission testing to show compliance with 93115.6(a)(4)</p>																																																									
	<table border="1"> <thead> <tr> <th colspan="5" data-bbox="426 1227 1388 1283">Table 2: Emission Standards for New Stationary Emergency Standby Direct-Drive Fire Pump Engines &gt; 50 BHP – g/bhp-hr (g/kW-hr)</th> </tr> <tr> <th data-bbox="426 1283 624 1339">Maximum engine power</th> <th data-bbox="624 1283 874 1339">Model year(s)</th> <th data-bbox="874 1283 1050 1339">PM</th> <th data-bbox="1050 1283 1225 1339">NMHC + NOx</th> <th data-bbox="1225 1283 1388 1339">CO</th> </tr> </thead> <tbody> <tr> <td data-bbox="426 1339 624 1406" rowspan="2">50≤HP&lt;100 (37≤kW&lt;75)</td> <td data-bbox="624 1339 874 1373">2010 and earlier</td> <td data-bbox="874 1339 1050 1373">0.60 (0.80)</td> <td data-bbox="1050 1339 1225 1373">7.8 (10.5)</td> <td data-bbox="1225 1339 1388 1406" rowspan="2">3.7 (5.0)</td> </tr> <tr> <td data-bbox="624 1373 874 1406">2011+</td> <td data-bbox="874 1373 1050 1406">0.30 (0.40)</td> <td data-bbox="1050 1373 1225 1406">3.5 (4.7)</td> </tr> <tr> <td data-bbox="426 1406 624 1462" rowspan="2">100≤HP&lt;175 (75≤kW&lt;130)</td> <td data-bbox="624 1406 874 1440">2009 and earlier</td> <td data-bbox="874 1406 1050 1440">0.60 (0.80)</td> <td data-bbox="1050 1406 1225 1440">7.8 (10.5)</td> <td data-bbox="1225 1406 1388 1462" rowspan="2">3.7 (5.0)</td> </tr> <tr> <td data-bbox="624 1440 874 1462">2010+</td> <td data-bbox="874 1440 1050 1462">0.22 (0.30)</td> <td data-bbox="1050 1440 1225 1462">3.0 (4.0)</td> </tr> <tr> <td data-bbox="426 1462 624 1529" rowspan="2">175≤HP&lt;300 (130≤kW&lt;225)</td> <td data-bbox="624 1462 874 1496">2008 and earlier</td> <td data-bbox="874 1462 1050 1496">0.40 (0.54)</td> <td data-bbox="1050 1462 1225 1496">7.8 (10.5)</td> <td data-bbox="1225 1462 1388 1529" rowspan="2">2.6 (3.5)</td> </tr> <tr> <td data-bbox="624 1496 874 1529">2009+</td> <td data-bbox="874 1496 1050 1529">0.15 (0.20)</td> <td data-bbox="1050 1496 1225 1529">3.0 (4.0)</td> </tr> <tr> <td data-bbox="426 1529 624 1597" rowspan="2">300≤HP&lt;600 (225≤kW&lt;450)</td> <td data-bbox="624 1529 874 1563">2008 and earlier</td> <td data-bbox="874 1529 1050 1563">0.40 (0.54)</td> <td data-bbox="1050 1529 1225 1563">7.8 (10.5)</td> <td data-bbox="1225 1529 1388 1597" rowspan="2">2.6 (3.5)</td> </tr> <tr> <td data-bbox="624 1563 874 1597">2009+</td> <td data-bbox="874 1563 1050 1597">0.15 (0.20)</td> <td data-bbox="1050 1563 1225 1597">3.0 (4.0)</td> </tr> <tr> <td data-bbox="426 1597 624 1664" rowspan="2">600≤HP&lt;750 (450≤kW&lt;560)</td> <td data-bbox="624 1597 874 1630">2008 and earlier</td> <td data-bbox="874 1597 1050 1630">0.40 (0.54)</td> <td data-bbox="1050 1597 1225 1630">7.8 (10.5)</td> <td data-bbox="1225 1597 1388 1664" rowspan="2">2.6 (3.5)</td> </tr> <tr> <td data-bbox="624 1630 874 1664">2009+</td> <td data-bbox="874 1630 1050 1664">0.15 (0.20)</td> <td data-bbox="1050 1630 1225 1664">3.0 (4.0)</td> </tr> <tr> <td data-bbox="426 1664 624 1720" rowspan="2">HP&gt;750 (kW&gt;560)</td> <td data-bbox="624 1664 874 1697">2007 and earlier</td> <td data-bbox="874 1664 1050 1697">0.40 (0.54)</td> <td data-bbox="1050 1664 1225 1697">7.8 (10.5)</td> <td data-bbox="1225 1664 1388 1720" rowspan="2">2.6 (3.5)</td> </tr> <tr> <td data-bbox="624 1697 874 1720">2008+</td> <td data-bbox="874 1697 1050 1720">0.15 (0.20)</td> <td data-bbox="1050 1697 1225 1720">4.8 (6.4)</td> </tr> </tbody> </table>	Table 2: Emission Standards for New Stationary Emergency Standby Direct-Drive Fire Pump Engines > 50 BHP – g/bhp-hr (g/kW-hr)					Maximum engine power	Model year(s)	PM	NMHC + NOx	CO	50≤HP<100 (37≤kW<75)	2010 and earlier	0.60 (0.80)	7.8 (10.5)	3.7 (5.0)	2011+	0.30 (0.40)	3.5 (4.7)	100≤HP<175 (75≤kW<130)	2009 and earlier	0.60 (0.80)	7.8 (10.5)	3.7 (5.0)	2010+	0.22 (0.30)	3.0 (4.0)	175≤HP<300 (130≤kW<225)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)	2009+	0.15 (0.20)	3.0 (4.0)	300≤HP<600 (225≤kW<450)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)	2009+	0.15 (0.20)	3.0 (4.0)	600≤HP<750 (450≤kW<560)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)	2009+	0.15 (0.20)	3.0 (4.0)	HP>750 (kW>560)	2007 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)	2008+	0.15 (0.20)
Table 2: Emission Standards for New Stationary Emergency Standby Direct-Drive Fire Pump Engines > 50 BHP – g/bhp-hr (g/kW-hr)																																																										
Maximum engine power	Model year(s)	PM	NMHC + NOx	CO																																																						
50≤HP<100 (37≤kW<75)	2010 and earlier	0.60 (0.80)	7.8 (10.5)	3.7 (5.0)																																																						
	2011+	0.30 (0.40)	3.5 (4.7)																																																							
100≤HP<175 (75≤kW<130)	2009 and earlier	0.60 (0.80)	7.8 (10.5)	3.7 (5.0)																																																						
	2010+	0.22 (0.30)	3.0 (4.0)																																																							
175≤HP<300 (130≤kW<225)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)																																																						
	2009+	0.15 (0.20)	3.0 (4.0)																																																							
300≤HP<600 (225≤kW<450)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)																																																						
	2009+	0.15 (0.20)	3.0 (4.0)																																																							
600≤HP<750 (450≤kW<560)	2008 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)																																																						
	2009+	0.15 (0.20)	3.0 (4.0)																																																							
HP>750 (kW>560)	2007 and earlier	0.40 (0.54)	7.8 (10.5)	2.6 (3.5)																																																						
	2008+	0.15 (0.20)	4.8 (6.4)																																																							

District/Agency	Best Available Control Technology (BACT)/Requirements		
SMAQMD	<p><b><u>BACT</u></b>            Source: SMAQMD BACT Clearinghouse, BACT Determination Number 111</p>		
	<p>For standby units with a rating of <math>\geq 50</math> HP</p>		
	<table border="1"> <tr> <td data-bbox="416 517 528 636">VOC</td> <td data-bbox="528 517 1402 636">Applicable NMHC + NO<sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines</td> </tr> </table>	VOC	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines
	VOC	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines	
	<table border="1"> <tr> <td data-bbox="416 636 528 754">NO<sub>x</sub></td> <td data-bbox="528 636 1402 754">Applicable NMHC + NO<sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines</td> </tr> </table>	NO <sub>x</sub>	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines
	NO <sub>x</sub>	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines	
	<table border="1"> <tr> <td data-bbox="416 754 528 819">SO<sub>x</sub></td> <td data-bbox="528 754 1402 819">CARB Diesel; Diesel fuel with a sulfur content no greater than 0.0015% by weight</td> </tr> </table>	SO <sub>x</sub>	CARB Diesel; Diesel fuel with a sulfur content no greater than 0.0015% by weight
	SO <sub>x</sub>	CARB Diesel; Diesel fuel with a sulfur content no greater than 0.0015% by weight	
	<table border="1"> <tr> <td data-bbox="416 819 528 907">PM<sub>10</sub></td> <td data-bbox="528 819 1402 907">0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines</td> </tr> </table>	PM <sub>10</sub>	0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines
	PM <sub>10</sub>	0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines	
<table border="1"> <tr> <td data-bbox="416 907 528 994">PM<sub>2.5</sub></td> <td data-bbox="528 907 1402 994">0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines</td> </tr> </table>	PM <sub>2.5</sub>	0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines	
PM <sub>2.5</sub>	0.15 g/bhp-hr (filterable)*, Compliance with the emission standards based on NSPS, Subpart IIII, Compliance with the emission standards based on the ATCM for Stationary Engines		
<table border="1"> <tr> <td data-bbox="416 994 528 1113">CO</td> <td data-bbox="528 994 1402 1113">Applicable NMHC + NO<sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines</td> </tr> </table>	CO	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines	
CO	Applicable NMHC + NO <sub>x</sub> Standard for horsepower range; Compliance with the emissions standards based on NSPS, Subpart IIII; Compliance with the emission standards based on the ATCM for Stationary CI Engines		
<p>*Note: BACT Determination Number 111 did not discuss the different requirements for direct drive fire-pump engines. Because direct-drive fire pumps less than 175 hp have different operation requirements, state and federal regulations require them to meet a standard greater than 0.15 g/hp-hr, and therefore, 0.15 g/hp-hr is not achieved in practice for direct-drive fire pump engines less than 175 hp.</p>			
<p><b><u>T-BACT</u></b>            The current BACT determination does not address T-BACT. However, the District's Stationary Internal Combustion Engine Policy Manual (May 2012) requires:</p> <ol style="list-style-type: none"> <li>1. Engines located within 1000 feet of a K-12 school shall not operate for maintenance purposes between the hours of 7:30 AM and 3:30 PM on days when school is in session. Engines meeting a PM emissions standard of 0.01 g/hp-hr or less are not subject to this restriction. This requirement applies only to maintenance operation and in no way limits operation of the engine for emergency purposes or operation at the request of SMAQMD staff for the purposes of determining compliance with emissions limits.</li> <li>2. Engines located on the grounds of a K-12 school are further prohibited from maintenance operation during any school sponsored activity. This requirement applies only to maintenance operation and in no way limits operation of the engine for emergency purposes or operation at the request of SMAQMD staff for the purposes of determining compliance with emissions limits.</li> </ol> <p><b><u>RULE REQUIREMENTS:</u></b>            None</p>			



District/Agency	Best Available Control Technology (BACT)/Requirements																																																																						
South Coast AQMD	<p><b>BACT</b>            Source: <a href="#">SCAQMD BACT Guidelines for Non-Major Polluting Facilities, page 69-72</a></p> <table border="1" data-bbox="424 483 1388 734"> <thead> <tr> <th colspan="6">BACT Guideline, I.C. Engine, Stationary, Emergency – g/kW-hr (g/bhp-hr)</th> </tr> <tr> <th>Maximum engine power</th> <th>Tier</th> <th>NMHC + NOx</th> <th>SOx</th> <th>CO</th> <th>PM</th> </tr> </thead> <tbody> <tr> <td>50≤HP&lt;100</td> <td>3</td> <td>4.7 (3.5)</td> <td rowspan="5">0.0015% S by weight in fuel</td> <td>5.0 (3.7)</td> <td>0.40 (0.30)</td> </tr> <tr> <td>100≤HP&lt;175</td> <td>3</td> <td>4.0 (3.0)</td> <td>5.0 (3.7)</td> <td>0.30 (0.22)</td> </tr> <tr> <td>175≤HP&lt;300</td> <td>3</td> <td>4.0 (3.0)</td> <td>3.5 (2.6)</td> <td>0.20 (0.75)</td> </tr> <tr> <td>300≤HP&lt;750</td> <td>3</td> <td>4.0 (3.0)</td> <td>3.5 (2.6)</td> <td>0.20 (0.75)</td> </tr> <tr> <td>HP&gt;750</td> <td>2</td> <td>6.4 (4.8)</td> <td>3.5 (2.6)</td> <td>0.20 (0.75)</td> </tr> </tbody> </table> <p>T-BACT            There are no T-BACT standards published in the clearinghouse for this category.</p> <p><b>RULE REQUIREMENTS:</b>  <a href="#">Reg XI, Rule 1110.2 – Emissions From Gaseous- and Liquid-Fueled Engines</a>            Standby Engines are exempt from the emission limitations of this rule.  <a href="#">Reg XVI, Rule 1470 – Requirements for Stationary Diesel-Fueled Internal Combustion and Other Compression Ignition Engines</a>            This rule regulates criteria pollutants as well as diesel PM from stationary diesel engines. Rule 1470 is not a SIP-approved rule so the standards below will only be considered for purposes of establishing “achieved in practice” T-BACT control levels or techniques.</p> <table border="1" data-bbox="424 1167 1388 1563"> <thead> <tr> <th colspan="4">SCAQMD Rule 1470 Emission Standards – g/kW-hr (g/bhp-hr)</th> </tr> <tr> <th colspan="4">Rule 1470 §(c)(2)(C)(vi) for PM</th> </tr> <tr> <th colspan="4">Rule 1470 §(c)(2)(C)(vii), Table 2 for NMHC + NOx, and CO</th> </tr> <tr> <th>Maximum engine power</th> <th>NMHC + NOx</th> <th>CO</th> <th>PM</th> </tr> </thead> <tbody> <tr> <td>50 &lt; HP &lt; 100 (37 &lt; kW &lt; 75)</td> <td>4.7 (3.5)</td> <td>5.0 (3.7)</td> <td>(0.15)</td> </tr> <tr> <td>100 &lt; HP &lt; 175 (75 &lt; kW &lt; 130)</td> <td>4.0 (3.0)</td> <td>5.0 (3.7)</td> <td>(0.15)</td> </tr> <tr> <td>175 &lt; HP ≤ 750 (130 &lt; kW ≤ 560)</td> <td>4.0 (3.0)</td> <td>3.5 (2.6)</td> <td>(0.15)</td> </tr> <tr> <td>HP &gt; 750 (kW &gt; 560)</td> <td>6.4 (4.8)</td> <td>3.5 (2.6)</td> <td>(0.15)</td> </tr> </tbody> </table> <p>For standby diesel fueled direct drive fire pump engines, SCAQMD Rule 1470 requires the engine to meet the same emission standards as Table 2 of the Stationary Diesel ATCM (Title 17, Cal. Code Regs., §93116(a)(4))</p>	BACT Guideline, I.C. Engine, Stationary, Emergency – g/kW-hr (g/bhp-hr)						Maximum engine power	Tier	NMHC + NOx	SOx	CO	PM	50≤HP<100	3	4.7 (3.5)	0.0015% S by weight in fuel	5.0 (3.7)	0.40 (0.30)	100≤HP<175	3	4.0 (3.0)	5.0 (3.7)	0.30 (0.22)	175≤HP<300	3	4.0 (3.0)	3.5 (2.6)	0.20 (0.75)	300≤HP<750	3	4.0 (3.0)	3.5 (2.6)	0.20 (0.75)	HP>750	2	6.4 (4.8)	3.5 (2.6)	0.20 (0.75)	SCAQMD Rule 1470 Emission Standards – g/kW-hr (g/bhp-hr)				Rule 1470 §(c)(2)(C)(vi) for PM				Rule 1470 §(c)(2)(C)(vii), Table 2 for NMHC + NOx, and CO				Maximum engine power	NMHC + NOx	CO	PM	50 < HP < 100 (37 < kW < 75)	4.7 (3.5)	5.0 (3.7)	(0.15)	100 < HP < 175 (75 < kW < 130)	4.0 (3.0)	5.0 (3.7)	(0.15)	175 < HP ≤ 750 (130 < kW ≤ 560)	4.0 (3.0)	3.5 (2.6)	(0.15)	HP > 750 (kW > 560)	6.4 (4.8)	3.5 (2.6)	(0.15)
	BACT Guideline, I.C. Engine, Stationary, Emergency – g/kW-hr (g/bhp-hr)																																																																						
	Maximum engine power	Tier	NMHC + NOx	SOx	CO	PM																																																																	
	50≤HP<100	3	4.7 (3.5)	0.0015% S by weight in fuel	5.0 (3.7)	0.40 (0.30)																																																																	
	100≤HP<175	3	4.0 (3.0)		5.0 (3.7)	0.30 (0.22)																																																																	
	175≤HP<300	3	4.0 (3.0)		3.5 (2.6)	0.20 (0.75)																																																																	
	300≤HP<750	3	4.0 (3.0)		3.5 (2.6)	0.20 (0.75)																																																																	
	HP>750	2	6.4 (4.8)		3.5 (2.6)	0.20 (0.75)																																																																	
	SCAQMD Rule 1470 Emission Standards – g/kW-hr (g/bhp-hr)																																																																						
	Rule 1470 §(c)(2)(C)(vi) for PM																																																																						
Rule 1470 §(c)(2)(C)(vii), Table 2 for NMHC + NOx, and CO																																																																							
Maximum engine power	NMHC + NOx	CO	PM																																																																				
50 < HP < 100 (37 < kW < 75)	4.7 (3.5)	5.0 (3.7)	(0.15)																																																																				
100 < HP < 175 (75 < kW < 130)	4.0 (3.0)	5.0 (3.7)	(0.15)																																																																				
175 < HP ≤ 750 (130 < kW ≤ 560)	4.0 (3.0)	3.5 (2.6)	(0.15)																																																																				
HP > 750 (kW > 560)	6.4 (4.8)	3.5 (2.6)	(0.15)																																																																				

District/Agency	Best Available Control Technology (BACT)/Requirements																												
South Coast AQMD (continued)	<p>Rule 1470, §§(c)(2)(A), (c)(2)(C)(iv), and (c)(2)(C)(v) place additional restrictions on engines located on school grounds, within 100 meters of a school, within 500 feet of a school, and within 50 meters of a sensitive receptor. For engines located within 100 meters of a school or on school grounds, the engine must emit diesel PM at a rate less than or equal to 0.01 g/hp-hr, unless the owner/operator accepts restrictions on non-emergency operation (7:30 a.m. to 4:30 p.m. when school is in session or during school activities) in most cases. New engines located within 500 feet of as school must meet an emission standard of 0.15 g/hp-hr and not operate for non-emergency use between the hours of 7:30 a.m. and 3:30 p.m. when school is in session. Except for replacement engines, new stationary emergency engines located within 50 meters of a sensitive receptor are required to meet Tier 4 PM standards for nonroad engines.</p>																												
San Joaquin Valley Unified APCD APCD	<p><b>BACT</b>            Source: <a href="#">SJVUAPCD BACT Guideline 3.1.1</a></p> <table border="1" data-bbox="424 891 1396 1137"> <thead> <tr> <th colspan="2">Emergency Diesel IC engine</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>Latest EPA Tier Certification level for applicable horsepower range*</td> </tr> <tr> <td>NOx</td> <td>Latest EPA Tier Certification level for applicable horsepower range*</td> </tr> <tr> <td>SOx</td> <td>Very low sulfur diesel fuel (15 ppmw sulfur or less)</td> </tr> <tr> <td>PM10</td> <td>0.15 g/bhp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)</td> </tr> <tr> <td>PM2.5</td> <td>No standard</td> </tr> <tr> <td>CO</td> <td>Latest EPA Tier Certification level for applicable horsepower range*</td> </tr> </tbody> </table> <p>*Note: for emergency engines <math>50 \leq \text{bhp} &lt; 75</math>, Tier 4 Interim certification is the requirement; for emergency engines <math>75 \leq \text{bhp} &lt; 750</math>, Tier 3 certification is the requirement; for emergency engines <math>\Rightarrow 750</math> bhp, Tier 2 certification is the requirement.</p> <p><b>BACT</b>            Source: <a href="#">SJVUAPCD BACT Guideline 3.1.4</a></p> <table border="1" data-bbox="424 1373 1396 1653"> <thead> <tr> <th colspan="2">Emergency Diesel I.C. Engine Driving a Fire Pump</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>Positive crankcase ventilation [unless it voids the Underwriters Laboratories (UL) certification]</td> </tr> <tr> <td>NOx</td> <td>Certified NOx emissions of 6.9 g/bhp-hr or less</td> </tr> <tr> <td>SOx</td> <td>Low-sulfur diesel fuel (500 ppmw sulfur or less) or Very Low-sulfur diesel fuel (15 ppmw sulfur or less), where available.</td> </tr> <tr> <td>PM10</td> <td>0.4 g/bhp-hr</td> </tr> <tr> <td>PM2.5</td> <td>No standard</td> </tr> <tr> <td>CO</td> <td>No standard</td> </tr> </tbody> </table>	Emergency Diesel IC engine		VOC	Latest EPA Tier Certification level for applicable horsepower range*	NOx	Latest EPA Tier Certification level for applicable horsepower range*	SOx	Very low sulfur diesel fuel (15 ppmw sulfur or less)	PM10	0.15 g/bhp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)	PM2.5	No standard	CO	Latest EPA Tier Certification level for applicable horsepower range*	Emergency Diesel I.C. Engine Driving a Fire Pump		VOC	Positive crankcase ventilation [unless it voids the Underwriters Laboratories (UL) certification]	NOx	Certified NOx emissions of 6.9 g/bhp-hr or less	SOx	Low-sulfur diesel fuel (500 ppmw sulfur or less) or Very Low-sulfur diesel fuel (15 ppmw sulfur or less), where available.	PM10	0.4 g/bhp-hr	PM2.5	No standard	CO	No standard
Emergency Diesel IC engine																													
VOC	Latest EPA Tier Certification level for applicable horsepower range*																												
NOx	Latest EPA Tier Certification level for applicable horsepower range*																												
SOx	Very low sulfur diesel fuel (15 ppmw sulfur or less)																												
PM10	0.15 g/bhp-hr or the Latest EPA Tier Certification level for applicable horsepower range, whichever is more stringent. (ATCM)																												
PM2.5	No standard																												
CO	Latest EPA Tier Certification level for applicable horsepower range*																												
Emergency Diesel I.C. Engine Driving a Fire Pump																													
VOC	Positive crankcase ventilation [unless it voids the Underwriters Laboratories (UL) certification]																												
NOx	Certified NOx emissions of 6.9 g/bhp-hr or less																												
SOx	Low-sulfur diesel fuel (500 ppmw sulfur or less) or Very Low-sulfur diesel fuel (15 ppmw sulfur or less), where available.																												
PM10	0.4 g/bhp-hr																												
PM2.5	No standard																												
CO	No standard																												

District/Agency	Best Available Control Technology (BACT)/Requirements														
San Joaquin Valley Unified APCD (continued)	<p><b>T-BACT</b>            Source: <a href="#">SJVUAPCD BACT Guideline 3.1.4</a></p> <table border="1" data-bbox="426 488 1388 577"> <tr> <td colspan="2">Emergency Diesel I.C. Engine Driving a Fire Pump</td> </tr> <tr> <td>Diesel PM</td> <td>0.149 g/hp-hr, if T-BACT is triggered based on a site-specific health risk analysis</td> </tr> </table> <p>There are no T-BACT standards published in the clearinghouse for non-fire pump emergency diesel I.C. engines.</p> <p><b>RULE REQUIREMENTS:</b>  <a href="#">Rule 4702 – INTERNAL COMBUSTION ENGINES</a></p> <p>Standby Engines are exempt from the emission limitations of this rule.</p>	Emergency Diesel I.C. Engine Driving a Fire Pump		Diesel PM	0.149 g/hp-hr, if T-BACT is triggered based on a site-specific health risk analysis										
Emergency Diesel I.C. Engine Driving a Fire Pump															
Diesel PM	0.149 g/hp-hr, if T-BACT is triggered based on a site-specific health risk analysis														
San Diego County APCD	<p><b>BACT</b>            Source: <a href="#">NSR Requirements for BACT</a>            The engine BACT determinations listed in the SDAPCD Clearinghouse do not apply to standby engines.</p> <p><b>T-BACT</b>            There are no T-BACT standards published in the clearinghouse for this category.</p> <p><b>RULE REQUIREMENTS:</b>  <a href="#">Regulation 4, Rule 69.4 – Stationary Reciprocating Internal Combustion Engines – Reasonably Available Control Technology</a>            This rule applies to stationary I.C. Engines ≥ 50 BHP located at a stationary source which emits or has a potential to emit 50 tons per year or more of NOx.</p> <p>Standby Engines are exempt from the emission limitations of this rule.</p> <p><a href="#">Regulation 4, Rule 69.4.1 – Stationary Reciprocating Internal Combustion Engines – Best Available Retrofit Control Technology</a>            This rule applies to stationary I.C. Engines ≥ 50 BHP.</p> <table border="1" data-bbox="426 1458 1388 1675"> <tr> <td colspan="2">New or replacement low-use engines using diesel or kerosene fuel</td> </tr> <tr> <td>VOC</td> <td>No standard</td> </tr> <tr> <td>NOx</td> <td>6.9 g/bhp-hr or 535 ppmv</td> </tr> <tr> <td>SOx</td> <td>California Diesel Fuel</td> </tr> <tr> <td>PM10</td> <td>No standard</td> </tr> <tr> <td>PM2.5</td> <td>No standard</td> </tr> <tr> <td>CO</td> <td>No standard</td> </tr> </table>	New or replacement low-use engines using diesel or kerosene fuel		VOC	No standard	NOx	6.9 g/bhp-hr or 535 ppmv	SOx	California Diesel Fuel	PM10	No standard	PM2.5	No standard	CO	No standard
New or replacement low-use engines using diesel or kerosene fuel															
VOC	No standard														
NOx	6.9 g/bhp-hr or 535 ppmv														
SOx	California Diesel Fuel														
PM10	No standard														
PM2.5	No standard														
CO	No standard														

District/Agency	Best Available Control Technology (BACT)/Requirements			
Bay Area AQMD	<p><b>BACT</b>            Source: <a href="#">BAAQMD BACT Guideline 96.1.3</a></p>			
	<p>IC Engine-Compression Ignition: Stationary Emergency, non-Agricultural, non-direct drive fire pump ≥ 50 BHP</p>			
	<table border="1"> <tr> <td data-bbox="416 546 528 577">VOC</td> <td data-bbox="528 546 1399 577">ARB ATCM standard for NMHC at applicable horsepower rating</td> </tr> </table>	VOC	ARB ATCM standard for NMHC at applicable horsepower rating	
	VOC	ARB ATCM standard for NMHC at applicable horsepower rating		
	<table border="1"> <tr> <td data-bbox="416 577 528 609">NOx</td> <td data-bbox="528 577 1399 609">ARB ATCM standard for NOx at applicable horsepower rating</td> </tr> </table>	NOx	ARB ATCM standard for NOx at applicable horsepower rating	
	NOx	ARB ATCM standard for NOx at applicable horsepower rating		
	<table border="1"> <tr> <td data-bbox="416 609 528 640">SOx</td> <td data-bbox="528 609 1399 640">Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm (wt)</td> </tr> </table>	SOx	Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm (wt)	
	SOx	Fuel sulfur content not to exceed 0.0015% (wt) or 15 ppm (wt)		
	<table border="1"> <tr> <td data-bbox="416 640 528 672">PM10</td> <td data-bbox="528 640 1399 672">0.15 g/bhp-hr</td> </tr> </table>	PM10	0.15 g/bhp-hr	
	PM10	0.15 g/bhp-hr		
<table border="1"> <tr> <td data-bbox="416 672 528 703">PM2.5</td> <td data-bbox="528 672 1399 703">No standard</td> </tr> </table>	PM2.5	No standard		
PM2.5	No standard			
<table border="1"> <tr> <td data-bbox="416 703 528 734">CO</td> <td data-bbox="528 703 1399 734">ARB ATCM standard for CO at applicable horsepower rating</td> </tr> </table>	CO	ARB ATCM standard for CO at applicable horsepower rating		
CO	ARB ATCM standard for CO at applicable horsepower rating			
<p><b>T-BACT</b>            Source: <a href="#">BAAQMD BACT Guideline 96.1.3</a></p>				
<p>IC Engine-Compression Ignition: Stationary Emergency, non-Agricultural, non-direct drive fire pump ≥ 50 BHP</p>				
<table border="1"> <tr> <td data-bbox="416 916 528 947">Diesel</td> <td data-bbox="528 916 1399 947">0.15 g/bhp-hr</td> </tr> <tr> <td data-bbox="416 947 528 978">PM</td> <td data-bbox="528 947 1399 978"></td> </tr> </table>	Diesel	0.15 g/bhp-hr	PM	
Diesel	0.15 g/bhp-hr			
PM				
<p><b>RULE REQUIREMENTS:</b>  <a href="#">Reg 9, Rule 8 – Nitrogen Oxides and Carbon Monoxide from Stationary Internal Combustion Engines</a>             Standby Engines are exempt from the emission limitations of this rule.</p>				

The following control technologies have been identified and are ranked based on stringency:

<b>SUMMARY OF ACHIEVED IN PRACTICE CONTROL TECHNOLOGIES</b>	
<b>VOC</b>	<ol style="list-style-type: none"> <li>1. Applicable NMHC + NOx emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD]</li> <li>2. Applicable NMHC + NOx emission standard for horsepower range based on 40 CFR 60 Subpart IIII [EPA].</li> <li>3. No Standard [SDAPCD]</li> </ol>
<b>NOx</b>	<ol style="list-style-type: none"> <li>1. Applicable NMHC + NOx emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD]</li> <li>2. Applicable NMHC + NOx emission standard for horsepower range based on 40 CFR 60 Subpart IIII [EPA].</li> <li>3. 6.9 g/bhp-hr or 535 ppmv [SDAPCD]</li> </ol>
<b>SOx</b>	<ol style="list-style-type: none"> <li>1. Diesel fuel with a sulfur content no greater than 0.0015% by weight [EPA, ARB, SMAQMD, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD]</li> </ol>
<b>PM10</b>	<ol style="list-style-type: none"> <li>1. Applicable PM emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [ARB, SMAQMD, SJVUAPCD, BAAQMD]</li> <li>2. Applicable PM emission standard for horsepower range based on 40 CFR 60 Subpart IIII or 40 CFR 63 Subpart ZZZZ, whichever is more stringent. [EPA]</li> <li>3. No Standard [SDAPCD]</li> </ol>
<b>PM2.5</b>	<ol style="list-style-type: none"> <li>1. Applicable PM emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [SMAQMD]</li> <li>2. Applicable PM emission standard for horsepower range based on 40 CFR 60 Subpart IIII or 40 CFR 63 Subpart ZZZZ, whichever is more stringent [EPA]</li> <li>3. No Standard [ARB, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD]</li> </ol>
<b>CO</b>	<ol style="list-style-type: none"> <li>1. Applicable CO emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD]</li> <li>2. Applicable CO emission standard for horsepower range based on 40 CFR 60 Subpart IIII. [EPA]</li> <li>3. No Standard [SDAPCD]</li> </ol>
<b>Diesel PM (T-BACT)</b>	<ol style="list-style-type: none"> <li>1. Compliance with SCAQMD Rule 1470<sup>(C)</sup> [SCAQMD]</li> <li>2. 0.149 g/hp-hr if T-BACT is triggered for a direct-drive fire pump [SJVUAPCD]</li> <li>3. 0.15 g/bhp-hr for stationary emergency, non-agricultural, non-direct drive fire pump ≥ 50 BHP</li> <li>4. Applicable PM emission standard for horsepower range <sup>(A),(B)</sup> based on the ATCM for Stationary CI Engines. [ARB, BAAQMD, SJVUAPCD]</li> <li>5. Applicable PM emission standard for horsepower range based on 40 CFR 60 subpart IIII, 40 CFR 63 Subpart ZZZZ. [EPA]</li> </ol>

(A) for non-direct drive fire pump emergency engines  $50 \leq \text{bhp} < 75$ , Tier 4 Interim certification is the requirement; for emergency engines  $75 \leq \text{bhp} < 750$ , Tier 3 certification is the requirement; for emergency engines  $\geq 750$  bhp, Tier 2 certification is the requirement.

(B) for direct-drive fire pump emergency engines, the applicable standards are those listed in Table 2 of the Stationary Diesel ATCM (Title 17, Cal. Code Regs., §93116(a)(4))

(C) SCAQMD Rule 1470 requires new engines (as of January 1, 2013) located within 50 meters of a sensitive receptor that are not replacement engines to meet Tier 4 emission standards for PM.

The following control technologies have been identified as the most stringent, achieved in practice control technologies:

<b>BEST CONTROL TECHNOLOGIES ACHIEVED IN PRACTICE</b>		
<b>Pollutant</b>	<b>Standard</b>	<b>Source</b>
VOC	Applicable NMHC + NOx emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
NOx	Applicable NMHC + NOx emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
SOx	Diesel fuel with a sulfur content no greater than 0.0015% by weight.	EPA, ARB, SMAQMD, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD
PM10	Applicable PM emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
PM2.5	Applicable PM emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	SMAQMD; EPA
CO	Applicable CO emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
Diesel PM (T-BACT)	Applicable PM emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	EPA, ARB, SMAQMD, SCAQMD <sup>(B)</sup> , SJVUAPCD <sup>(A)</sup> , SDAPCD, BAAQMD

- On 6/30/2001, SJVUAPCD last updated their T-BACT standard for diesel PM. This standard requires direct-drive fire pump engines to meet a PM standard of 0.1 g/hp-hr (later clarified to be 0.149 g/bhp-hr). Subsequent to this (September 27, 2004), the Air Resources Board adopted the ATCM for stationary diesel engines. During the rulemaking process, ARB initially proposed 0.1 g/hp-hr as the standard, but eventually established the PM standards to be 0.15 g/hp-hr, which was discussed during a public workshop on April 4, 2002. Also subsequent to this, South Coast AQMD determined in their analysis on Rule 1470 (May 4, 2012) that, except in certain cases, due to NFPA requirements, requiring PM standards more stringent than the NSPS is cost prohibitive because manufacturers cannot justify different PM standards on fire pumps for such a small market. As a result Rule 1470 allows direct-drive fire pump engines to meet the NSPS standards, except when installed within 100 meters of a school. For these reasons, the District has determined that the PM

standard of SJVUAPCD T-BACT Guideline 3.4.1 is not achieved in practice and therefore is not listed in the above table.

- SCAQMD Rule 1470 requires a more stringent PM emission standard for engines greater or equal to 175 HP if the engine is going to be located within 50 meters from a sensitive receptor. The rule analysis states that cancer risk from emergency diesel engines could be as high as 11 per million for receptors within 50 meters of the release point. This is greater than the 10 in a million significance level for the SCAQMD. Therefore, SCAQMD justified the requirement that most new emergency-use diesel engines meet more stringent standards for PM when installed within 50 meters of a sensitive receptor. Rule 1470 is not considered achieved in practice for SMAQMD for the following reasons:
  - It requires more stringent PM standards for engines  $\geq$  175 HP when installed within 50 meters from sensitive receptors because the cancer risk may exceed 10 in one million. SMAQMD does not allow a cancer risk in excess of 10 in one million.
  - It allows operation of the engine for emergency purposes if the electrical operating reserves fall below 5% (Stage II). SMAQMD allows emergency operation only during unforeseeable power outages.
  - It allows the use of the engine in Demand Response Programs (DRP). SMAQMD allows emergency operation only during unforeseeable power outages.

## **B. TECHNOLOGICALLY FEASIBLE AND COST EFFECTIVE (Rule 202, §205.1.b.):**

### **Discussion**

During the most recent rulemaking for updates to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines (Title 17, Cal. Code. Regs., §93115 to §93115.15), ARB conducted a cost effectiveness analysis to determine if selective catalytic reduction (SCR) and/or diesel particulate filters (DPF) were technologically feasible and cost effective for emergency use applications. (Initial Statement of Reasons for Proposed Rulemaking: Proposed Amendments to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines, Appendix B, September 2010)

The analysis concluded that DPFs were technologically feasible with some additional operational and monitoring conditions. These conditions would include either operating the engine for additional hours to allow the filter to regenerate (Passive DPF) or regenerating the filter during scheduled down-time (active DPF), and monitoring for backpressure, cold starts, and 30-minute idle sessions.

The analysis also concluded that SCR was technologically feasible, but had some additional challenges. Because standby engines routinely operate only for scheduled maintenance and testing, the engines do not operate more than 15-30 minutes, and do operate at no or low load. Because of this the exhaust would not likely reach the temperature (260 °C to 540 °C) required for the catalyst to operate. To circumvent this problem, the engine would need to be operated with higher loads and in many cases for longer periods of time. This could be a challenge for most emergency standby applications as most businesses do not have load banks in house and would have to create a larger load on the engine to get the catalyst up to operational temperature.

Urea handling and maintenance is also an important consideration. Urea crystallization in the lines can cause damage to the SCR system and to the engine itself. Crystallization in the lines is more likely in emergency standby engines due to their periodic and low hours of usage. Urea also has a shelf life of approximately two years. This could increase the cost of operating a SCR for emergency standby engines since the low number of annual hours of operation experienced by most emergency standby engines could lead to urea expiration. The urea would then have to be drained and replaced, creating an extra maintenance step and an increased cost to the end user.

ARB staff determined that while, SCR systems may be technically feasible, there are significant operational hurdles to overcome before routine use of SCR on emergency standby engines is practical. This is because the majority of operating hours for emergency standby engines occur during short 15 to 30 minute maintenance and testing checks are at low engine loads. In most cases, the temperature needed for the SCR catalyst to function will not be reached during this operation and the SCR will not provide the expected NOx reductions.

ARB staff also reviewed the feasibility of requiring Tier 4 final engines in lieu of aftermarket treatment. ARB concluded that Tier 4 engines that rely on after-treatment technology for emergency standby applications will not be available from the original equipment manufacturers. Representatives from the Engine Manufacturer's Association (EMA) have indicated that it will not be economically viable for engine manufacturers to develop and maintain a Tier 4 emergency standby engine platform for California. At the time, ARB staff



concluded that Tier 4 engines for emergency standby applications will not be available “off-the-shelf.” Rather, each owner or operator will need to purchase a new Tier 2 or Tier 3 engines and then work with suppliers to retrofit the engine with a DPF and/or SCR to meet the Tier 4 emission standards for all pollutants. Subsequent to this “off-the-shelf” Tier 4 final engines have become available for emergency purposes, and the District determined that Tier 4 final engines are technologically feasible. The District reviewed some engine list prices and determined that these prices were generally in line with the prices listed in Appendix B.

**Technologically Feasible Alternatives:**

Any alternative basic equipment, fuel, process, emission control device or technique, singly or in combination, determined to be technologically feasible by the Air Pollution Control Officer.

The table below shows the technologically feasible alternatives identified as capable of reducing emissions beyond the levels determined to be “Achieved in Practice” as per Rule 202, §205.1.a.

<b>VOC</b>	Tier 4 standard
<b>NOx</b>	Selective Catalytic Reduction (SCR) Tier 4 standard
<b>SOx</b>	No other technologically feasible option identified
<b>PM10</b>	Diesel Particulate Filter (DPF) Tier 4 standard
<b>PM2.5</b>	Diesel Particulate Filter (DPF) Tier 4 standard
<b>CO</b>	Tier 4 standard

**Cost Effective Determination:**

After identifying the technologically feasible control options, a cost analysis is performed to take into consideration economic impacts for all technologically feasible controls identified.

The District reviewed cost information from the September 2010 amendments to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines and adjusted the assumptions to reflect permitted emissions for maintenance and testing (50 hr/year) and a 15-year life for the control equipment. The District concluded that conducting the cost analysis using 200 hours per year for total operation (maintenance, testing, and emergency use) was not representative of actual engine operation, since emergency use is not predictable or routine. Cost effectiveness for PM reductions from a Tier 4 interim or Tier 4 final are not presented below, since the cost increases due to controls were consistently higher than those for retrofitting. The results are presented in the below tables.

Cost-Effectiveness Associated with the Application of DPF and SCR on Emergency Standby Engines (50 hours/year)							
Regulatory Scenario			HP Range				
			50-174	175-749	750-1206	1207-1999	>2000
	Average Horsepower:		112	462	978	1604	2630
Scenario 1: DPF Retrofit of Tier 2/3 engine	Cost Increase Due to Controls (A)	PM	\$4,300	\$17,600	\$37,200	\$60,900	\$99,900
		NOx	N/A	N/A	N/A	N/A	N/A
	Emission Reductions (lb) (B)	PM	13	53	113	186	305
		NOx	N/A	N/A	N/A	N/A	N/A
	Cost Effectiveness (\$/lb)	PM	\$333	\$331	\$329	\$328	\$328
		NOx	N/A	N/A	N/A	N/A	N/A
Scenario 2: DPF/SCR Retrofit of Tier 2/3 engine	Cost Increase Due to Controls (A)	PM	\$4,400	\$18,200	\$38,500	\$63,100	\$103,400
		NOx	\$8,800	\$36,300	\$76,900	\$126,100	\$206,900
	Emission Reductions (lb) (B)	PM	13	53	113	186	305
		NOx	161	666	2348	3677	6032
	Cost Effectiveness (\$/lb)	PM	\$341	\$342	\$341	\$340	\$339
		NOx	\$55	\$54	\$33	\$34	\$34

(A) Cost increases due to controls are from Table B-7 of the Initial Statement of Reasons for Proposed Rulemaking: Proposed Amendments to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines, Appendix B, September 2010.

(B) Emission reductions have been adjusted from 31 hours/year of operation to 50 hours/year of operation.

Cost-Effectiveness Associated with installing Tier 4 Final Emergency Standby Engines (50 hours/year)							
Regulatory Scenario			HP Range				
			50-174	175-749	750-1206	1207-1999	>2000
	Average Horsepower:		112	462	978	1604	2630
Tier 4 Final Engine	Cost Increase (A)	NOx	\$28,000	\$85,008	\$156,480	\$248,465	\$328,750
	Emission Reductions (lb) (B)	NOx	161	666	2,348	3,677	6,032
	Cost Effectiveness (\$/lb)	NOx	\$170	\$130	\$70	\$70	\$50

(A) Cost increases due to controls are from Table B-7 of the Initial Statement of Reasons for Proposed Rulemaking: Proposed Amendments to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines, Appendix B, September 2010.

(B) Emission reductions have been adjusted from 31 hours/year of operation to 50 hours/year of operation.

The above cost effectiveness numbers were converted from cost per pound to cost per ton for comparison to the District's cost effectiveness thresholds.

Cost-Effectiveness Associated with the Application of DPF and SCR on Emergency Standby Engines (50 hours/year)							
Regulatory Scenario			HP Range				
			50-174	175-749	750-1206	1207-1999	>2000
	Average Horsepower:		112	462	978	1604	2630
Scenario 1: DPF Retrofit of Tier 2/3 engine	Cost Effectiveness (\$/ton)	PM	\$660,000	\$662,000	\$658,000	\$656,000	\$656,000
		NOx	N/A	N/A	N/A	N/A	N/A
Scenario 2: DPF/SCR Retrofit of Tier 2/3 engine	Cost Effectiveness (\$/ton)	PM	\$682,000	\$684,000	\$682,000	\$680,000	\$678,000
		NOx	\$110,000	\$108,000	\$66,000	\$68,000	\$68,000
Scenario 3: Tier 4 Final engine	Cost Effectiveness (\$/ton)	NOx	\$340,000	\$260,000	\$140,000	\$140,000	\$100,000

As demonstrated above, SCR and DPF after treatment is not considered cost effective since both the cost effectiveness for reducing the pollutants exceeds the District's threshold of \$24,500 for NOx and \$11,400 for PM10.

**C. SELECTION OF BACT:**

Based on the above analysis, BACT for VOC, NOx, SOx, PM10, and CO will remain at what is currently achieved in practice and BACT for PM2.5 will be set to be the same as for PM10.

<b>BACT FOR I.C. ENGINES, STANDBY, DIESEL-FUELED</b>		
<b>Pollutant</b>	<b>Standard</b>	<b>Source</b>
VOC	Applicable NMHC + NOx emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
NOx	Applicable NMHC + NOx emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
SOx	Diesel fuel with a sulfur content no greater than 0.0015% by weight.	EPA, ARB, SMAQMD, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD
PM10	Applicable PM emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD
PM2.5	Applicable PM emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	SMAQMD; EPA
CO	Applicable CO emission standard for horsepower range based on Table 1: New Emergency Standby Diesel-Fueled CI Engines and Table 2: New Emergency Standby Direct-Drive Fire Pump Engines of the <a href="#">ATCM for Stationary CI Engines</a> .	ARB, SMAQMD, SCAQMD, SJVUAPCD, BAAQMD

<b>T-BACT FOR I.C. ENGINES, STANDBY, DIESEL-FUELED</b>		
<b>Pollutant</b>	<b>Standard</b>	<b>Source</b>
Diesel PM	Applicable PM emission standard for horsepower range based on the ATCM for Stationary CI Engines	EPA, ARB, SMAQMD, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD

REVIEWED BY: \_\_\_\_\_ DATE: \_\_\_\_\_

APPROVED BY:  \_\_\_\_\_ DATE: **1/12/16**

# **Attachment A**

**Review of BACT Determinations published by EPA**

List of BACT determinations published in EPA's RACT/BACT/LAER Clearinghouse (RBLC) for I.C. Engines 175 ≥ HP > 750 <sup>(A)</sup>:

RBLC#	Permit Date	Process Code <sup>(B), (C)</sup>	Rating	Pollutant	Standard	Case-By-Case Basis
AK-0081	6/12/2013	17.110	610 BHP	PM2.5	0.1500 g/KW-hr	Other Case-by-Case; NSPS <sup>(D)</sup>
AK-0081	6/12/2013	17.210	493 BHP	PM2.5	0.2000 g/KW-hr	Other Case-by-Case; NSPS <sup>(D)</sup>
IA-0105	10/26/2012	17.110	2,682 BHP	PM	0.2000 g/KW-hr	BACT-PSD
IA-0105	10/26/2012	17.110	2,682 BHP	PM10	0.2000 g/KW-hr	BACT-PSD
IA-0105	10/26/2012	17.110	2,682 BHP	PM2.5	0.2000 g/KW-hr	BACT-PSD
IA-0105	10/26/2012	17.110	2,682 BHP	NOx	6.0000 g/KW-hr	BACT-PSD <sup>(E)</sup>
IA-0105	10/26/2012	17.110	2,682 BHP	VOC	0.4000 g/KW-hr	BACT-PSD <sup>(E)</sup>
IA-0105	10/26/2012	17.110	2,682 BHP	CO	3.5000 g/KW-hr	BACT-PSD
AK-0076	8/20/2012	17.110	2,347 BHP	NOx	6.4000 g/KW-hr	BACT-PSD; NSPS
AK-0076	8/20/2012	17.110	2,347 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
AK-0076	8/20/2012	17.110	2,347 BHP	PM2.5	0.2000 g/KW-hr	BACT-PSD; NSPS
MI-0395	7/13/2012	17.110	4,035 BHP	NOx	5.9800 g/KW-hr	BACT-PSD; NSPS, NESHAP, SIP, OPERATING PERMIT <sup>(F)</sup>
MI-0395	7/13/2012	17.110	3,634 BHP	NOx	7.1300 g/KW-hr	BACT-PSD; NSPS, NESHAP, SIP, OPERATING PERMIT <sup>(G)</sup>
SC-0159	7/9/2012	17.110	1,341 BHP	VOC	6.4000 g/KW-hr	BACT-PSD; NSPS <sup>(D)</sup>
SC-0113	2/28/2012	17.110	757 BHP	NOx	4.0000 g/KW-hr	BACT-PSD; NSPS <sup>(D)</sup>
SC-0113	2/28/2012	17.110	757 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS <sup>(D)</sup>
SC-0113	2/28/2012	17.110	757 BHP	VOC	4.0000 g/KW-hr	BACT-PSD; NSPS <sup>(D)</sup>
SC-0113	2/28/2012	17.110	757 BHP	SOx	0.0015% Sulfur	BACT-PSD
MI-0394	2/26/2012	17.110	4,035 BHP	NOx	5.9800 g/KW-hr	BACT-PSD; NSPS, NESHAP, SIP, OPERATING PERMIT <sup>(F)</sup>
MI-0394	2/26/2012	17.110	3,058 BHP	NOx	6.9300 g/KW-hr	BACT-PSD; NSPS, NESHAP, SIP, OPERATING PERMIT <sup>(G)</sup>

RBLC#	Permit Date	Process Code (B), (C)	Rating	Pollutant	Standard	Case-By-Case Basis
SC-0113	2/8/2012	17.210	500 BHP	NOx	4.0000 g/KW-hr	BACT-PSD; NSPS (D)
SC-0113	2/8/2012	17.210	500 BHP	SOx	0.0015% Sulfur	BACT-PSD
SC-0113	2/8/2012	17.210	500 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS (D)
SC-0113	2/8/2012	17.210	500 BHP	VOC	4.0000 g/KW-hr	BACT-PSD; NSPS (D)
CA-1212	10/18/2011	17.210	182 BHP	NOx	4.0000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.210	182 BHP	CO	3.5000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.210	182 BHP	PM10	0.2000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.210	182 BHP	PM2.5	0.2000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.110	2,683 BHP	NOx	6.4000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.110	2,683 BHP	CO	3.5000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.110	2,683 BHP	PM (TSP)	0.2000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.110	2,683 BHP	PM10	0.2000 g/KW-hr	BACT-PSD (H)
CA-1212	10/18/2011	17.110	2,683 BHP	PM2.5	0.2000 g/KW-hr	BACT-PSD (H)
FL-0332	9/23/2011	17.110	600 BHP	NOx + NMHC	3.000 g/hp-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	600 BHP	SOx	0.0015% Sulfur	BACT-PSD; NSPS
FL-0332	9/23/2011	17.110	600 BHP	PM (TSP)	0.1500 g/hp-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	600 BHP	CO	2.600 g/hp-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	2,682 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	2,682 BHP	PM	0.2000 g/KW-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	2,682 BHP	NOx	6.4000 g/KW-hr	BACT-PSD; NSPS (D)
FL-0332	9/23/2011	17.110	2,682 BHP	SOx	0.0015% Sulfur	BACT-PSD
LA-0254	8/16/2011	17.210	350 BHP	PM10	0.1500 g/hp-hr	BACT-PSD; NSPS (I)
LA-0254	8/16/2011	17.210	350 BHP	PM2.5	0.1500 g/hp-hr	BACT-PSD; NSPS (I)
LA-0254	8/16/2011	17.210	350 BHP	CO	2.6000 g/hp-hr	BACT-PSD; NSPS (I)

RBLC#	Permit Date	Process Code (B), (C)	Rating	Pollutant	Standard	Case-By-Case Basis
LA-0254	8/16/2011	17.210	350 BHP	VOC	1.0000 g/hp-hr	BACT-PSD; NSPS <sup>(I)</sup>
LA-0254	8/16/2011	17.110	1,250 BHP	PM2.5	0.1500 g/hp-hr	BACT-PSD; NSPS <sup>(I)</sup>
LA-0254	8/16/2011	17.110	1,250 BHP	PM10	0.1500 g/hp-hr	BACT-PSD; NSPS <sup>(I)</sup>
LA-0254	8/16/2011	17.110	1,250 BHP	CO	2.6000 g/hp-hr	BACT-PSD; NSPS <sup>(I)</sup>
LA-0254	8/16/2011	17.110	1,250 BHP	VOC	1.0000 g/hp-hr	BACT-PSD; NSPS <sup>(I)</sup>
CA-1192	6/21/2011	17.210	288 BHP	CO	0.4470 g/hp-hr	BACT-PSD; NSPS <sup>(J)</sup>
CA-1192	6/21/2011	17.210	288 BHP	NOx	3.4000 g/hp-hr	BACT-PSD; NSPS <sup>(J)</sup>
CA-1192	6/21/2011	17.210	288 BHP	PM (TSP)	NA	BACT-PSD; NSPS <sup>(J)</sup>
CA-1192	6/21/2011	17.210	288 BHP	PM10	NA	BACT-PSD; NSPS <sup>(J)</sup>
LA-0251	4/26/2011	17.110	591 BHP	NOx + NMHC	6.4000 g/KW-hr	LAER; NSPS
LA-0251	4/26/2011	17.110	591 BHP	PM10	0.2000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.110	591 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.210	193 BHP	PM10	0.2000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.210	193 BHP	NOx + NMHC	4.0000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.210	193 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.110	1,175 BHP	PM10	0.2000 g/KW-hr	BACT-PSD; NSPS
LA-0251	4/26/2011	17.110	1,175 BHP	NOx	6.4000 g/KW-hr	LAER; NSPS
LA-0251	4/26/2011	17.110	1,175 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
FL-0324	12/23/2010	17.210	400 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS <sup>(K)</sup>
FL-0324	12/23/2010	17.210	400 BHP	PM	0.2000 g/KW-hr	BACT-PSD; NSPS <sup>(K)</sup>
FL-0324	12/23/2010	17.210	400 BHP	SOx	0.0015% Sulfur	BACT-PSD; NSPS <sup>(K)</sup>
FL-0324	12/23/2010	17.210	400 BHP	NOx	4.0000 g/KW-hr	BACT-PSD; NSPS <sup>(K)</sup>
FL-0322	12/23/2010	17.110	2,682 BHP	CO	3.5000 g/KW-hr	BACT-PSD
FL-0322	12/23/2010	17.110	2,682 BHP	PM	0.2000 g/KW-hr	BACT-PSD





RBLC#	Permit Date	Process Code (B), (C)	Rating	Pollutant	Standard	Case-By-Case Basis
FL-0322	12/23/2010	17.110	2,682 BHP	NOx	6.4000 g/KW-hr	BACT-PSD
ID-0018	6/25/2010	17.110	1,006 BHP	NOx	6.4000 g/KW-hr	BACT-PSD; NSPS
ID-0018	6/25/2010	17.110	1,006 BHP	VOC	6.4000 g/KW-hr	BACT-PSD; NSPS
ID-0018	6/25/2010	17.110	1,006 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
ID-0018	6/25/2010	17.110	1,006 BHP	PM	0.2000 g/KW-hr	BACT-PSD; NSPS
CA-1191	3/11/2010	17.210	182 BHP	CO	3.5000 g/KW-hr	BACT-PSD
CA-1191	3/11/2010	17.210	182 BHP	NOx	3.8000 g/KW-hr	BACT-PSD; NSPS (L)
CA-1191	3/11/2010	17.210	182 BHP	PM (TSP)	0.2000 g/KW-hr	BACT-PSD
CA-1191	3/11/2010	17.210	182 BHP	PM2.5	0.2000 g/KW-hr	BACT-PSD
CA-1191	3/11/2010	17.110	2,683 BHP	CO	3.5000 g/KW-hr	BACT-PSD; NSPS
CA-1191	3/11/2010	17.110	2,683 BHP	NOx	6.0000 g/KW-hr	BACT-PSD; NSPS (L)
CA-1191	3/11/2010	17.110	2,683 BHP	PM (TSP)	0.2000 g/KW-hr	BACT-PSD

- (A) Due to the large number of entries only determinations made (based on Permit Date) entered since 01/01/2010 are included in the above table.
- (B) Process Code 17.110 includes Large Internal Combustion Engines (> 500 BHP) fueled using Fuel Oil (ASTM #1, 2, includes kerosene, aviation, diesel fuel. Determinations for engines  $\geq$  750 HP were exclude.
- (C) Process Code 17.210 includes Small Internal Combustion Engines ( $\leq$  500 BHP) fueled using Fuel Oil (ASTM #1, 2, includes kerosene, aviation, diesel fuel. Determinations for engines < 175 HP were excluded.
- (D) Emission Limits are based on [40 CFR Part 60 Subpart IIII – Standards of Performance for Stationary Compression Internal Combustion Engines](#). (NSPS, Subpart IIII)
- (E) Emission standards for NOx and VOC based on the NSPS, Subpart IIII and the California Tier Emission Standards are based on the sum of NOx and non-methane hydrocarbons (NMHC). Emission standard assumes 6.0 g/KW-hr NOx and 0.4 g/KW-hr VOC and will be based on source testing. Source Iowa DNR, PSD Permit 12-219.
- (F) No add-on controls, but ignition timing retardation (ITR) is good design. Engines are tuned for low-NOx operation versus low CO operation. DRUPS stands for Diesel Rotary Uninterruptable Power supply system. The system provides for zero down-time in electrical energy supply at the onset of a power outage. The system stores energy in a fly-wheel that powers the generator until the diesel engine starts up.
- (G) No add-on controls, but ignition timing retardation (ITR) is good design. Engines are tuned for low-NOx operation versus low CO operation.
- (H) Emission Limits are based on based on NSPS Subpart IIII emission standards and California Air Resources Board Tier 3 emission standards. Source: EPA Region IX PSD Permit Number [SE 09-01](#) for Palmdale Hybrid Power Project.
- (I) BACT was determined to be the use of a Tier 2 (non-road) engine, ultra low sulfur diesel and good combustion practices to achieve the emission limits on an annual basis. Source: Louisiana Department of Environmental Quality Permit [PSD-LA-752](#) for Ninemile Point Electical

Generating Plant

- (J) The Ninth Circuit Court of Appeals issued a decision on 8/12/2014 that vacated the permit decision and remanded it to EPA. Therefore, this BACT determination has not yet been achieved in practice. Source: EPA Region IX, [Avenal Energy Product](#).
- (K) Emission Limits are based on based on NSPS Subpart IIII emission standards. Source: Florida Department of Environmental Protection Permit [PSD-FL-413](#) for the Solid Waste Authority of Palm Beach County.
- (L) Emission standards for NOx in the NSPS, Subpart IIII and the California Tier Emission Standards are based on the sum of NOx and non-methane hydrocarbons (NMHC). For the NOx emission limits, the applicant assumes NMHC + NOx emissions from the engine are 95% NOx. Source: EPA Region IX PSD Permit Number [SE 07-02](#) for Victorville 2 Hybrid Power Project.

 = Not enough information provided to determine if engine is used for standby purposes.

 = Not applicable to this determination. Equipment has not yet been achieved in practice or is for a specific purpose outside of the scope of this determination.

 = Selected as the most stringent BACT determination achieved in practice.

Note: The above BACT determinations were compared to the emissions limits required by NSPS, Subpart IIII. The above emissions limits are the same as the NSPS, Subpart III requirements for the same model year and horsepower range. Therefore, the most stringent BACT is compliance with NSPS, Subpart IIII.

# **Attachment B**

**Review of BACT Determinations published by ARB**


List of BACT determinations published in ARB's BACT Clearinghouse for engines > 50 HP:


Capacity	Source	Date	NOx	VOC	CO	PM10
2,835 BHP	<a href="#">SCAQMD</a>	8/26/2003	50 ppmvd @ 15% O <sub>2</sub> <sup>(A)</sup>	39 ppmvd @ 15% O <sub>2</sub> <sup>(A)</sup>	89 ppmvd @ 15% O <sub>2</sub> <sup>(A)</sup>	0.045 g/bhp-hr <sup>(A)</sup>
1,030 BHP	<a href="#">SDAPCD</a>	6/14/2001	54 ppmvd @ 15% O <sub>2</sub> <sup>(A)</sup>	NA	450 ppmvd @ 15% O <sub>2</sub> <sup>(A)</sup>	NA
450 BHP	<a href="#">SCAQMD</a>	8/23/2012	1.8 g/KW-hr <sup>(B)</sup>	NA	NA	NA

(A) Add-on control – SCR system and diesel particulate filter.

(B) Tier 4 Interim Certified

 = Engines outside the range (Not in the 175 ≤ BHP <750 range)

 = Engines not used for standby puposes

 = Selected as the most stringent BACT determination achieved in practice.

Note: All three BACT determinations are for prime-use engines and are therefore not applicable to standby engines.

# **Attachment C**

## **Cost Effectiveness Calculations**