



BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION

DETERMINATION NO.: 122 & 123

DATE: July 5, 2016

ENGINEER: Jeffrey Quok

Category/General Equip

Description:

Internal Combustion (I.C.) Engine

Equipment Specific Description:

I.C. Engine Spark – Standby, Gaseous-fueled and Propane/LPG

Equipment Size/Rating:

Engines < 500 BHP (BACT #122)

Engines ≥ 500 BHP (BACT #123)

Previous BACT Det. No.:

No. 50

This BACT determination will update the following determinations:

#50 which was made on August 16, 2011 for I.C. Engine Spark - Standby, > 50 BHP

Additionally, this determination is being updated to include T-BACT for volatile hazardous air pollutants (VHAP) associated with gaseous fuel combustion.

BACT/T-BACT ANALYSIS

A. ACHIEVED IN PRACTICE (Rule 202, §205.1a):

The following control technologies are currently employed as BACT/T-BACT for gaseous-fueled and propane/LPG standby engines by the following agencies and air pollution control districts:

Note: Tables 3.2-1, 3.2-2, and 3.2-3 of AP-42 list benzene, formaldehyde, PAHs, naphthalene, acetaldehyde, acrolein, propylene, toluene, xylenes, ethyl benzene, and hexane as the primary drivers for health risks associated with natural gas combustion. These VHAPs/organic compounds are emitted as VOC and the same control technologies that control VOCs also control the listed VHAPs.

District/Agency	Best Available Control Technology (BACT)/Requirements																													
US EPA	<p>BACT Source: EPA RACT/BACT/LAER Clearinghouse (See Attachment A) RBLC ID: MD-0036 (VOC, PM10, & CO) & MI-0390 (NOx)</p> <table border="1" data-bbox="434 517 1398 734"> <thead> <tr> <th colspan="2">For standby natural gas (includes propane & LPG) units with a rating of ≥ 500 BHP</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>0.6 g/bhp-hr (MD-0036)^(A)</td> </tr> <tr> <td>NOx</td> <td>0.5 g/bhp-hr (MI-0390)^(B)</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the ≥ 500 BHP range</td> </tr> <tr> <td>PM10</td> <td>0.0099 lb/MMBtu (MD-0036)</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the ≥ 500 BHP range</td> </tr> <tr> <td>CO</td> <td>1.5 g/bhp-hr (MD-0036)</td> </tr> </tbody> </table> <p>(A) MD-0036 was a BACT Determination for a 1,085 BHP engine. This determination did not identify if the engine was lean or rich burn. (B) MI-0390 was a BACT Determination for a 1,818 BHP engine. This determination did not identify if the engine was lean or rich burn.</p>	For standby natural gas (includes propane & LPG) units with a rating of ≥ 500 BHP		VOC	0.6 g/bhp-hr (MD-0036) ^(A)	NOx	0.5 g/bhp-hr (MI-0390) ^(B)	SOx	N/A – No BACT determinations found in the ≥ 500 BHP range	PM10	0.0099 lb/MMBtu (MD-0036)	PM2.5	N/A – No BACT determinations found in the ≥ 500 BHP range	CO	1.5 g/bhp-hr (MD-0036)															
	For standby natural gas (includes propane & LPG) units with a rating of ≥ 500 BHP																													
	VOC	0.6 g/bhp-hr (MD-0036) ^(A)																												
	NOx	0.5 g/bhp-hr (MI-0390) ^(B)																												
	SOx	N/A – No BACT determinations found in the ≥ 500 BHP range																												
	PM10	0.0099 lb/MMBtu (MD-0036)																												
	PM2.5	N/A – No BACT determinations found in the ≥ 500 BHP range																												
	CO	1.5 g/bhp-hr (MD-0036)																												
	<table border="1" data-bbox="434 902 1398 1120"> <thead> <tr> <th colspan="2">For standby natural gas(includes propane & LPG) units with a rating of < 500 BHP</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> <tr> <td>NOx</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> <tr> <td>SOx</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> <tr> <td>PM10</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> <tr> <td>PM2.5</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> <tr> <td>CO</td> <td>N/A – No BACT determinations found in the < 500 BHP range</td> </tr> </tbody> </table> <p>RBLC ID: N/A</p>	For standby natural gas(includes propane & LPG) units with a rating of < 500 BHP		VOC	N/A – No BACT determinations found in the < 500 BHP range	NOx	N/A – No BACT determinations found in the < 500 BHP range	SOx	N/A – No BACT determinations found in the < 500 BHP range	PM10	N/A – No BACT determinations found in the < 500 BHP range	PM2.5	N/A – No BACT determinations found in the < 500 BHP range	CO	N/A – No BACT determinations found in the < 500 BHP range															
	For standby natural gas(includes propane & LPG) units with a rating of < 500 BHP																													
VOC	N/A – No BACT determinations found in the < 500 BHP range																													
NOx	N/A – No BACT determinations found in the < 500 BHP range																													
SOx	N/A – No BACT determinations found in the < 500 BHP range																													
PM10	N/A – No BACT determinations found in the < 500 BHP range																													
PM2.5	N/A – No BACT determinations found in the < 500 BHP range																													
CO	N/A – No BACT determinations found in the < 500 BHP range																													
<p>T-BACT There are no T-BACT standards published in the clearinghouse for this category.</p>																														
<p>RULE REQUIREMENTS: 40 CFR Part 60 Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines: This regulation applies to owners/operators of new stationary spark ignition engines that commenced construction after June 12, 2006. [40 CFR §60.4230(a)(4)]</p>																														
<p>40 CFR §60.4233(d) & §60.4233(e) Owners and operators of stationary SI ICE with a maximum engine power greater than 19 KW (25 BHP) must comply with the emission standards of Table 1 to this subpart for their emergency stationary SI ICE (applies to both lean and rich burn engines).</p>																														
<table border="1" data-bbox="434 1624 1398 1937"> <thead> <tr> <th colspan="6">40 CFR Subpart JJJJ Table 1: Emission Standards (g/kW-hr)</th> </tr> <tr> <th rowspan="3">Engine Type and Fuel</th> <th rowspan="3">Maximum Engine Power</th> <th rowspan="3">Manufacture Date</th> <th colspan="3">Emission Standards^(A)</th> </tr> <tr> <th colspan="3">g/bhp-hr (ppmvd at 15% O₂)</th> </tr> <tr> <th>NOx</th> <th>CO</th> <th>VOC^(C)</th> </tr> </thead> <tbody> <tr> <td>Emergency^(D)</td> <td>25<BHP<130</td> <td>1/1/2009</td> <td>10^(B) (N/A)</td> <td>387 (N/A)</td> <td>N/A</td> </tr> <tr> <td></td> <td>BHP≥130</td> <td></td> <td>2.0 (160)</td> <td>4.0 (540)</td> <td>1.0 (86)</td> </tr> </tbody> </table>	40 CFR Subpart JJJJ Table 1: Emission Standards (g/kW-hr)						Engine Type and Fuel	Maximum Engine Power	Manufacture Date	Emission Standards ^(A)			g/bhp-hr (ppmvd at 15% O ₂)			NOx	CO	VOC ^(C)	Emergency ^(D)	25<BHP<130	1/1/2009	10 ^(B) (N/A)	387 (N/A)	N/A		BHP≥130		2.0 (160)	4.0 (540)	1.0 (86)
40 CFR Subpart JJJJ Table 1: Emission Standards (g/kW-hr)																														
Engine Type and Fuel	Maximum Engine Power	Manufacture Date	Emission Standards ^(A)																											
			g/bhp-hr (ppmvd at 15% O ₂)																											
			NOx	CO	VOC ^(C)																									
Emergency ^(D)	25<BHP<130	1/1/2009	10 ^(B) (N/A)	387 (N/A)	N/A																									
	BHP≥130		2.0 (160)	4.0 (540)	1.0 (86)																									

District/Agency	Best Available Control Technology (BACT)/Requirements														
US EPA	<p>(A) Owners and operators of stationary non-certified SI engines may choose to comply with the emission standards in units of either g/bhp-hr or ppmvd at 15% O₂</p> <p>(B) The emission standards applicable to emergency engines between 25 BHP and 130 BHP are in terms of NO_x + HC.</p> <p>(C) For purposes of this subpart, when calculating emissions of VOC compounds, emissions of formaldehyde should not be included.</p> <p>(D) Applies to both lean and rich burn emergency engines.</p>														
Air Resources Board (ARB)	<p>BACT Source: ARB BACT Clearinghouse (SCAQMD) (See Attachment B)</p> <table border="1" data-bbox="440 739 1394 958"> <thead> <tr> <th colspan="2" data-bbox="440 739 1394 770">For standby spark ignition natural gas fired units^(A)</th> </tr> </thead> <tbody> <tr> <td data-bbox="440 770 539 801">VOC</td> <td data-bbox="545 770 1394 801">1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller</td> </tr> <tr> <td data-bbox="440 801 539 833">NO_x</td> <td data-bbox="545 801 1394 833">1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller</td> </tr> <tr> <td data-bbox="440 833 539 864">SO_x</td> <td data-bbox="545 833 1394 864">N/A – No BACT determinations found</td> </tr> <tr> <td data-bbox="440 864 539 896">PM10</td> <td data-bbox="545 864 1394 896">N/A – No BACT determinations found</td> </tr> <tr> <td data-bbox="440 896 539 927">PM2.5</td> <td data-bbox="545 896 1394 927">N/A – No BACT determinations found</td> </tr> <tr> <td data-bbox="440 927 539 958">CO</td> <td data-bbox="545 927 1394 958">2.0 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller</td> </tr> </tbody> </table> <p>(A) This BACT determination was for a 1334 bhp engine. The determination doesn't specify if the engine is rich or lean burn.</p> <p>T-BACT There are no T-BACT standards published in the clearinghouse for this category.</p> <p>RULE REQUIREMENTS: None</p> <p>CARB RACT/BARCT Guidelines for Stationary Spark-Ignited Internal Combustion Engines (11/2001) This document presents the determination of reasonably available control technology (RACT) and best available retrofit control technology (BARCT) for controlling NO_x, VOC, and CO from stationary, spark-ignited reciprocating internal combustion engines. On page IV-14 of the document, emergency standby engines are listed as exempt from the recommended emission limits. Therefore this guideline is not applicable to this BACT determination.</p>	For standby spark ignition natural gas fired units ^(A)		VOC	1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller	NO _x	1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller	SO _x	N/A – No BACT determinations found	PM10	N/A – No BACT determinations found	PM2.5	N/A – No BACT determinations found	CO	2.0 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller
For standby spark ignition natural gas fired units ^(A)															
VOC	1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller														
NO _x	1.5 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller														
SO _x	N/A – No BACT determinations found														
PM10	N/A – No BACT determinations found														
PM2.5	N/A – No BACT determinations found														
CO	2.0 g/bhp-hr, 3-way catalyst converter with air/fuel ratio controller														

District/Agency	Best Available Control Technology (BACT)/Requirements		
SMAQMD	<p><u>BACT</u> Source: SMAQMD BACT Clearinghouse, BACT Determination Number 50 (8/16/11)</p>		
	<p>For standby spark ignition units with a rating of > 50 BHP^(A)</p>		
	<table border="1"> <tr> <td data-bbox="432 524 539 577">VOC</td> <td data-bbox="544 524 1401 577">50% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (0.29 g/bhp-hr for rich burn)^(B)</td> </tr> </table>	VOC	50% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (0.29 g/bhp-hr for rich burn) ^(B)
	VOC	50% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (0.29 g/bhp-hr for rich burn) ^(B)	
	<table border="1"> <tr> <td data-bbox="432 584 539 638">NOx</td> <td data-bbox="544 584 1401 638">85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (1.56 g/bhp-hr for rich burn)^(B)</td> </tr> </table>	NOx	85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (1.56 g/bhp-hr for rich burn) ^(B)
	NOx	85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (1.56 g/bhp-hr for rich burn) ^(B)	
	<table border="1"> <tr> <td data-bbox="432 645 539 672">SOx</td> <td data-bbox="544 645 1401 672">Natural Gas or Propane Fuel</td> </tr> </table>	SOx	Natural Gas or Propane Fuel
	SOx	Natural Gas or Propane Fuel	
	<table border="1"> <tr> <td data-bbox="432 678 539 705">PM10</td> <td data-bbox="544 678 1401 705">Natural Gas or Propane Fuel</td> </tr> </table>	PM10	Natural Gas or Propane Fuel
	PM10	Natural Gas or Propane Fuel	
<table border="1"> <tr> <td data-bbox="432 712 539 739">PM2.5</td> <td data-bbox="544 712 1401 739">No Standard</td> </tr> </table>	PM2.5	No Standard	
PM2.5	No Standard		
<table border="1"> <tr> <td data-bbox="432 745 539 799">CO</td> <td data-bbox="544 745 1401 799">85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (2.56 g/hp-hr for rich burn)^(B)</td> </tr> </table>	CO	85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (2.56 g/hp-hr for rich burn) ^(B)	
CO	85% Control Efficiency, 3-Way Catalyst with Air-to-Fuel Ratio Controller (2.56 g/hp-hr for rich burn) ^(B)		
<p>(A) The determination doesn't specify if the engine is rich or lean burn. (B) Control efficiency conversion to g/bhp-hr is based on uncontrolled emission factors from AP-42, Table 3.2-3 (7/00), and engine brake-specific fuel consumption (BSFC) from SBCAPCD <i>Piston IC Engine Technical Reference Document</i>, Table 6 (11/1/02).</p>			
<p><u>T-BACT</u> The current BACT determination does not address T-BACT.</p>			
<p><u>RULE REQUIREMENTS:</u> Rule 412 – Stationary Internal Combustion Engines Located at Major Stationary Sources of NOx (Adopted 6/1/1995) This rule applies to any stationary internal combustion engine rated at more than 50 BHP located at a major stationary source of NOx. Section 110 of this rule states that operation of stationary internal combustion engines used for emergency standby are exempt from the standards of this rule. Therefore, this rule is not applicable to this BACT determination.</p>			

District/Agency	Best Available Control Technology (BACT)/Requirements																						
South Coast AQMD	<p>BACT Source: SCAQMD BACT Guidelines for Non-Major Polluting Facilities, page 71-72 (10/3/08)</p> <table border="1" data-bbox="434 517 1385 786"> <thead> <tr> <th colspan="6">BACT Guideline, I.C. Engine Spark Ignition, Stationary, Emergency – g/bhp-hr (A)</th> </tr> <tr> <th>Maximum engine power</th> <th>VOC</th> <th>NOx</th> <th>SOx</th> <th>CO</th> <th>PM</th> </tr> </thead> <tbody> <tr> <td>All</td> <td>1.5 g/bhp-hr</td> <td>1.5 g/bhp-hr</td> <td>Use of clean fuels (B)</td> <td>2.0 g/bhp-hr</td> <td>Use of clean fuels (B)</td> </tr> </tbody> </table> <p>(A) This BACT determination applies to all engine BHP size ratings. (B) Clean fuel is defined as one that produces air emissions equivalent to or lower than natural gas for NOx, SOx, ROG, and fine particulate matter (PM10).</p> <p>T-BACT There are no T-BACT standards published in the clearinghouse for this category.</p> <p>RULE REQUIREMENTS: Reg IX, Rule 1110.2 – Emissions from Gaseous- and Liquid-Fueled Engines (Amended 12/4/15)</p> <p>Emergency standby engines are exempt from this Rule.</p>	BACT Guideline, I.C. Engine Spark Ignition, Stationary, Emergency – g/bhp-hr (A)						Maximum engine power	VOC	NOx	SOx	CO	PM	All	1.5 g/bhp-hr	1.5 g/bhp-hr	Use of clean fuels (B)	2.0 g/bhp-hr	Use of clean fuels (B)				
BACT Guideline, I.C. Engine Spark Ignition, Stationary, Emergency – g/bhp-hr (A)																							
Maximum engine power	VOC	NOx	SOx	CO	PM																		
All	1.5 g/bhp-hr	1.5 g/bhp-hr	Use of clean fuels (B)	2.0 g/bhp-hr	Use of clean fuels (B)																		
San Joaquin Valley Unified APCD	<p>BACT Source: SJVUAPCD BACT Guideline 3.1.5 – Emergency Gas-Fired IC Engine <132 BHP, Rich Burn (11/27/96) Guideline 3.1.6 – Emergency Gas-Fired IC Engine ≥132 BHP, Rich Burn (6/20/95) Guideline 3.1.8 – Emergency Gas-Fired IC Engine ≥250 BHP, Lean Burn (4/4/02)</p> <table border="1" data-bbox="434 1440 1407 1686"> <thead> <tr> <th colspan="2">Emergency Gas-Fired IC engine <132 BHP, Rich Burn</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>1. Positive crankcase ventilation (PCV) (Achieved in Practice) 2. VOC Catalyst (3 way) (Technologically Feasible)</td> </tr> <tr> <td>NOx</td> <td>NOx Catalyst (3 way) (Technologically Feasible)</td> </tr> <tr> <td>SOx</td> <td>No Standard</td> </tr> <tr> <td>PM10</td> <td>Positive crankcase ventilation (PCV) (Achieved in Practice)</td> </tr> <tr> <td>PM2.5</td> <td>No Standard</td> </tr> <tr> <td>CO</td> <td>CO Catalyst (3 Way) (Technologically Feasible)</td> </tr> </tbody> </table> <table border="1" data-bbox="434 1720 1407 1933"> <thead> <tr> <th colspan="2">Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</th> </tr> </thead> <tbody> <tr> <td>VOC</td> <td>1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice) 3. VOC Catalyst (Technologically Feasible)</td> </tr> <tr> <td>NOx</td> <td>1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. NOx Catalyst (Technologically Feasible)</td> </tr> <tr> <td>SOx</td> <td>Natural gas, LPG, or propane as fuel</td> </tr> </tbody> </table>	Emergency Gas-Fired IC engine <132 BHP, Rich Burn		VOC	1. Positive crankcase ventilation (PCV) (Achieved in Practice) 2. VOC Catalyst (3 way) (Technologically Feasible)	NOx	NOx Catalyst (3 way) (Technologically Feasible)	SOx	No Standard	PM10	Positive crankcase ventilation (PCV) (Achieved in Practice)	PM2.5	No Standard	CO	CO Catalyst (3 Way) (Technologically Feasible)	Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn		VOC	1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice) 3. VOC Catalyst (Technologically Feasible)	NOx	1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. NOx Catalyst (Technologically Feasible)	SOx	Natural gas, LPG, or propane as fuel
Emergency Gas-Fired IC engine <132 BHP, Rich Burn																							
VOC	1. Positive crankcase ventilation (PCV) (Achieved in Practice) 2. VOC Catalyst (3 way) (Technologically Feasible)																						
NOx	NOx Catalyst (3 way) (Technologically Feasible)																						
SOx	No Standard																						
PM10	Positive crankcase ventilation (PCV) (Achieved in Practice)																						
PM2.5	No Standard																						
CO	CO Catalyst (3 Way) (Technologically Feasible)																						
Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn																							
VOC	1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice) 3. VOC Catalyst (Technologically Feasible)																						
NOx	1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. NOx Catalyst (Technologically Feasible)																						
SOx	Natural gas, LPG, or propane as fuel																						

District/Agency	Best Available Control Technology (BACT)/Requirements						
San Joaquin Valley Unified APCD	<table border="1"> <tr> <td data-bbox="435 398 539 427">PM10</td> <td data-bbox="547 398 1399 461">1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice)</td> </tr> <tr> <td data-bbox="435 461 539 490">PM2.5</td> <td data-bbox="547 461 1399 490">No Standard</td> </tr> <tr> <td data-bbox="435 490 539 553">CO</td> <td data-bbox="547 490 1399 553">1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. CO Catalyst (Technologically Feasible)</td> </tr> </table>	PM10	1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice)	PM2.5	No Standard	CO	1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. CO Catalyst (Technologically Feasible)
	PM10	1. Positive Crankcase Ventilation (PCV) (Achieved in Practice) 2. Natural gas, LPG, or propane as fuel (Achieved in Practice)					
	PM2.5	No Standard					
	CO	1. Natural Gas, LPG, or propane as fuel (Achieved in Practice) 2. CO Catalyst (Technologically Feasible)					
	Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn						
	VOC	1. ≤ 1.0 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) (Achieved in Practice) 2. 90% control efficiency, oxidation catalyst or equivalent control (technologically feasible)					
	NOx	≤ 1.0 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) (Achieved in Practice)					
	SOx	No Standard					
	PM10	Natural gas fuel					
	PM2.5	No Standard					
	CO	≤ 2.75 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) (Achieved in Practice)					
	<p><u>T-BACT</u> There are no T-BACT standards published in the clearinghouse for this category.</p>						
	<p><u>RULE REQUIREMENTS:</u> Rule 4702 – INTERNAL COMBUSTION ENGINES (Amended 11/14/13)</p>						
	<p>Standby Engines are exempt from the emission limitations of this rule.</p>						
San Diego APCD	<p><u>BACT</u> Source: NSR Requirements for BACT The engine BACT determinations listed in the SDAPCD Clearinghouse do not apply to standby engines.</p>						
	<p><u>T-BACT</u> There are no T-BACT standards published in the clearinghouse for this category.</p>						
	<p><u>RULE REQUIREMENTS:</u> Regulation 4, Rule 69.4 – Stationary Reciprocating Internal Combustion Engines – Reasonably Available Control Technology (7/30/03) This rule applies to stationary I.C. Engines ≥ 50 BHP located at a stationary source which emits or has a potential to emit 50 tons per year or more of NOx.</p>						
	<p>Standby Engines are exempt from the emission limitations of this rule.</p>						
	<p>Regulation 4, Rule 69.4.1 – Stationary Reciprocating Internal Combustion Engines – Best Available Retrofit Control Technology (11/15/00) This rule applies to stationary I.C. Engines ≥ 50 BHP.</p>						

District/Agency	Best Available Control Technology (BACT)/Requirements			
San Diego APCD	New or replacement rich-burn engines using fossil derived gaseous fuel			
		Published Value	Conversion for Naturally Aspirated Engines (g/bhp-hr) ^(A)	Conversion for Turbocharged Engines (g/bhp-hr) ^(B)
	VOC	250 ppmvd @ 15% O ₂	1.53	1.47
	NOx	25 ppmvd @ 15% O ₂ OR 96% weight reduction	0.44	0.42
	SOx	No standard	-	-
	PM10	No standard	-	-
	PM2.5	No standard	-	-
	CO	4,500 ppmvd @ 15% O ₂	48.4	46.4
	(A) Based on <i>Santa Barbara County APCD Piston IC Engine Technical Reference Document</i> (11/1/02) emission factor conversions, Section II(B)(B7)(e)(vi).			
	(B) Based on <i>Santa Barbara County APCD Piston IC Engine Technical Reference Document</i> (11/1/02) emission factor conversions, Section II(B)(B7)(e)(vii).			
	New or replacement lean-burn engines using gaseous fuel			
		Published Value	Conversion for Naturally Aspirated Engines (g/bhp-hr) ^(A)	Conversion for Turbocharged Engines (g/bhp-hr) ^(B)
	VOC	250 ppmvd @ 15% O ₂	1.53	1.47
	NOx	65 ppmvd @ 15% O ₂ OR 90% weight reduction	1.14	1.10
SOx	No standard	-	-	
PM10	No standard	-	-	
PM2.5	No standard	-	-	
CO	4,500 ppmvd @ 15% O ₂	48.4	46.4	
(A) Based on <i>Santa Barbara County APCD Piston IC Engine Technical Reference Document</i> (11/1/02) emission factor conversions, Section II(B)(B7)(e)(vi).				
(B) Based on <i>Santa Barbara County APCD Piston IC Engine Technical Reference Document</i> (11/1/02) emission factor conversions, Section II(B)(B7)(e)(vii).				

District/Agency	Best Available Control Technology (BACT)/Requirements	
Bay Area AQMD	BACT Source: BAAQMD BACT Guideline 96.3.4 (5/7/03)	
	IC Engine - Spark Ignition, Natural Gas Fired Emergency Engine ≥ 50 BHP	
	VOC	1. 1.0 g/bhp-hr (Achieved in Practice) 2. Lean burn technology or equivalent (Achieved in Practice)
	NOx	1. 1.0 g/bhp-hr (Achieved in Practice) 2. Lean burn technology or equivalent (Achieved in Practice)
	SOx	1. Natural Gas Fuel (Achieved in Practice)
	PM10	1. Natural Gas Fuel (Achieved in Practice)
	PM2.5	No Standard

Bay Area AQMD	CO	1. 2.75 g/bhp-hr (Achieved in Practice) 2. Lean burn technology or equivalent (Achieved in Practice)
	<p>T-BACT There are no T-BACT standards published in the clearinghouse for this category.</p> <p>RULE REQUIREMENTS: Reg 9, Rule 8 – Nitrogen Oxides and Carbon Monoxide from Stationary Internal Combustion Engines (7/25/07)</p> <p>Standby Engines are exempt from the emission limitations of this rule.</p>	

The following control technologies have been identified and are ranked based on stringency:

SUMMARY OF ACHIEVED IN PRACTICE CONTROL TECHNOLOGIES	
VOC	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 50 BHP</u></p> <ol style="list-style-type: none"> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller [SMAQMD] (0.29 g/bhp-hr for rich burn engines) 1.0 g/bhp-hr [BAAQMD] 1.5 g/bhp-hr [SCAQMD] Lean burn technology or equivalent [BAAQMD] <p><u>For Spark Ignition, Emergency Standby Engines ≥ 500 BHP</u></p> <ol style="list-style-type: none"> 0.6 g/bhp-hr^(A) [EPA, MD-0036] <p><u>For rich-burn engines ≥ 50 BHP using fossil derived gaseous fuel or gasoline</u></p> <ol style="list-style-type: none"> 250 ppmvd @ 15% O₂ [SDAPCD] (1.53 g/bhp for naturally aspirated engines) (1.47 g/bhp for turbocharged engines) <p><u>For lean-burn engines ≥ 50 BHP using gaseous fuel</u></p> <ol style="list-style-type: none"> 250 ppmvd @ 15% O₂ [SDAPCD] (1.53 g/bhp for naturally aspirated engines) (1.47 g/bhp for turbocharged engines) <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u></p> <ol style="list-style-type: none"> Positive crankcase ventilation [SJVUAPCD] <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u></p> <ol style="list-style-type: none"> Positive crankcase ventilation [SJVUAPCD] Natural gas, LPG, or propane as fuel [SJVUAPCD] <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u></p> <ol style="list-style-type: none"> ≤ 1.0 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) [SJVUAPCD]
	NOx

NOx	<p><u>For rich-burn engines ≥ 50 BHP using fossil derived gaseous fuel or gasoline</u> 1. 25 ppmvd @ 15% O₂ OR 96% NOx weight reduction [SDAPCD] (0.44 g/bhp-hr for naturally aspirated engines) (0.42 g/bhp-hr for turbocharged engines)</p> <p><u>For lean-burn engines ≥ 50 BHP using gaseous fuel</u> 1. 65 ppmvd @ 15% O₂ OR 90% NOx weight reduction [SDAPCD] (1.14 g/bhp-hr for naturally aspirated engines) (1.10 g/bhp-hr for turbocharged engines)</p> <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u> 1. No achieved in practice standard [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u> 1. Natural gas, LPG, or propane as fuel [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u> 1. ≤ 1.0 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) [SJVUAPCD]</p>
SOx	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 50 BHP</u> 1. Natural gas or propane fuel [SMAQMD] 2. Natural gas fuel [BAAQMD] 3. Use of clean fuels^(C) [SCAQMD]</p> <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u> 1. No standard [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u> 1. Natural gas, LPG, or propane as fuel [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u> 1. No standard [SJVUAPCD]</p>
PM10	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 50 BHP</u> 1. Natural gas or propane fuel [SMAQMD] 2. Natural gas fuel [BAAQMD] 3. Use of clean fuels^(C) [SCAQMD]</p> <p><u>For Spark Ignition, Emergency Standby Engines ≥ 500 BHP</u> 1. 0.0099 lb/MMBtu [EPA, MD-0036]</p> <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u> 1. Positive crankcase ventilation [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u> 1. Positive crankcase ventilation [SJVUAPCD] 2. Natural gas, LPG, or propane as fuel [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u> 1. Natural gas fuel [SJVUAPCD]</p>
PM2.5	<p>1. No Standard [SMAQMD, SCAQMD, SJVUAPCD, SDAPCD, BAAQMD]</p>
CO	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 50 BHP</u> 1. 2.0 g/bhp-hr [SCAQMD] 2. 85% control efficiency, 3-way catalyst with air-to-fuel ratio controller [SMAQMD] (2.56 g/bhp-hr for rich burn engines) 3. 2.75 g/bhp-hr [BAAQMD] 4. Lean burn technology or equivalent [BAAQMD]</p>

CO	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 500 BHP</u> 1. 1.5 g/bhp-hr [EPA, MD-0036]</p> <p><u>For rich-burn engines ≥ 50 BHP using fossil derived gaseous fuel or gasoline</u> 1. 4,500 ppmvd @ 15% O₂ [SDAPCD] (48.4 g/bhp-hr for naturally aspirated engines) (46.4 g/bhp-hr for turbocharged engines)</p> <p><u>For lean-burn engines ≥ 50 BHP using gaseous fuel</u> 1. 4,500 ppmvd @ 15% O₂ [SDAPCD] (48.4 g/bhp-hr for naturally aspirated engines) (46.4 g/bhp-hr for turbocharged engines)</p> <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u> 1. No achieved in practice standard [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u> 1. Natural gas, LPG, or propane as fuel [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u> 1. ≤ 2.75 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) [SJVUAPCD]</p>
VHAP^(D) (T-BACT)	<p><u>For Spark Ignition, Emergency Standby Engines ≥ 50 BHP</u> 1. 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller [SMAQMD] (0.29 g/bhp-hr for rich burn engines) 2. 1.0 g/bhp-hr [BAAQMD] 3. 1.5 g/bhp-hr [SCAQMD] 4. Lean burn technology or equivalent [BAAQMD]</p> <p><u>For Spark Ignition, Emergency Standby Engines ≥ 500 BHP</u> 1. 0.6 g/bhp-hr^(A) [EPA, MD-0036]</p> <p><u>For rich-burn engines ≥ 50 BHP using fossil derived gaseous fuel or gasoline</u> 1. 250 ppmvd @ 15% O₂ [SDAPCD & ARB] (1.53 g/bhp for naturally aspirated engines) (1.47 g/bhp for turbocharged engines)</p> <p><u>For lean-burn engines ≥ 50 BHP using gaseous fuel</u> 1. 250 ppmvd @ 15% O₂ [SDAPCD & ARB] (1.53 g/bhp for naturally aspirated engines) (1.47 g/bhp for turbocharged engines)</p> <p><u>For Emergency Gas-Fired IC engines <132 BHP, Rich Burn</u> 1. Positive crankcase ventilation [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥132 BHP, Rich Burn</u> 1. Positive crankcase ventilation [SJVUAPCD] 2. Natural gas, LPG, or propane as fuel [SJVUAPCD]</p> <p><u>For Emergency Gas-Fired IC engine ≥250 BHP, Lean Burn</u> 1. ≤ 1.0 g/bhp-hr (Lean burn natural gas fired engine, or equivalent emissions) [SJVUAPCD]</p>

(A) MD-0036 was a BACT Determination for a 1,085 BHP engine. This determination did not identify if the engine was lean or rich burn.

(B) MI-0390 was a BACT Determination for a 1,818 BHP engine. This determination did not identify if the engine was lean or rich burn.

(C) Clean fuels is defined as one that produces air emissions equivalent to or lower than natural gas for NO_x, SO_x, ROG, and fine particulate matter (PM₁₀).

(D) A full list of the volatile hazardous air pollutants (VHAP) from natural gas combustion can be found in AP-42, Section 3.2 Natural Gas-fired Reciprocating Engines, Tables 3.2-1, 3.2-2, and 3.2-3.

The following control technologies have been identified as the most stringent, achieved in practice control technologies:

BEST CONTROL TECHNOLOGIES ACHIEVED		
Pollutant	Standard	Source
VOC	<u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u>	
	<u>Lean Burn</u> 1.0 g/bhp-hr	BAAQMD
	<u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines) ^(A)	SMAQMD
	<u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u>	
	<u>Lean Burn</u> 0.6 g/bhp-hr	EPA, MD-0036
	<u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines) ^(A)	SMAQMD
NOx	<u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas and rich-burn)</u>	
	<u>Lean Burn</u> 1.0 g/bhp-hr	BAAQMD
	<u>Rich Burn</u> 25 ppmvd @ 15% O ₂ OR 96% weight reduction (0.44 g/bhp-hr for naturally aspirated engines) (0.42 g/bhp-hr for turbocharged engines)	SDAPCD (Rule 69.4.1)
	<u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas and rich-burn)</u>	
	<u>Lean Burn</u> 0.5 g/bhp-hr	EPA, MI-0390
	<u>Rich Burn</u> 25 ppmvd @ 15% O ₂ OR 96% weight reduction (0.44 g/bhp-hr for naturally aspirated engines) (0.42 g/bhp-hr for turbocharged engines)	SDAPCD (Rule 69.4.1)

BEST CONTROL TECHNOLOGIES ACHIEVED		
Pollutant	Standard	Source
SO _x	<p><u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u> Natural gas or equivalent fuel</p> <p><u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u> Natural gas or equivalent fuel</p>	SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD
PM ₁₀	<p><u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u> Natural gas or equivalent fuel</p> <p><u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u> 0.0099 lb/MMBtu</p>	<p>SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD</p> <p>EPA (MD-0036)</p>
PM _{2.5} ^(A)	<p><u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u> Natural gas or equivalent fuel</p> <p><u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u> 0.0099 lb/MMBtu</p>	<p>SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD</p> <p>EPA (MD-0036)</p>
CO	<p><u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u> 2.0 g/bhp-hr</p> <p><u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u> 1.5 g/bhp-hr</p>	<p>SCAQMD</p> <p>EPA (MD-0036)</p>
VHAP	<p><u>For gaseous or propane/LPG fired emergency IC Engines < 500 BHP (excluding biogas)</u></p> <p><u>Lean Burn</u> 1.0 g/bhp-hr</p> <p><u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines)^(A)</p> <p><u>For gaseous or propane/LPG fired emergency IC Engines ≥ 500 BHP (excluding biogas)</u></p> <p><u>Lean Burn</u> 0.6 g/bhp-hr</p> <p><u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines)^(A)</p>	<p>BAAQMD</p> <p>SMAQMD</p> <p>EPA, MD-0036</p> <p>SMAQMD</p>

- (A) All PM is expected to be less than 1.0 micrometer in diameter and therefore PM10 BACT is equivalent to PM2.5 BACT.

B. TECHNOLOGICALLY FEASIBLE AND COST EFFECTIVE (Rule 202, §205.1.b.):

Technologically Feasible Alternatives:

Any alternative basic equipment, fuel, process, emission control device or technique, singly or in combination, determined to be technologically feasible by the Air Pollution Control Officer.

SJVUAPCD's BACT determination lists 3-way catalysts for rich burn emergency gas-fired engines as technologically feasible. However this BACT determination was last updated in 1996, and other districts have determined that 3-way catalysts are now achieved in practice. SMAQMD's BACT determination lists 3-way catalysts as achieved in practice for standby spark ignited engines.

During the most recent rulemaking for updates to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines (Title 17, Cal. Code. Regs., §93115 to §93115.15), ARB conducted a cost effectiveness analysis to determine if selective catalytic reduction (SCR) was technologically feasible and cost effective for emergency use applications. (Initial Statement of Reasons for Proposed Rulemaking: Proposed Amendments to the Airborne Toxic Control Measure for Stationary Compression Ignition Engines, Appendix B, September 2010). Although the analysis was for stationary compression ignition engines, the listed SCR challenges due to the operational nature of emergency standby engines is also applicable for stationary spark ignition engines.

The analysis concluded that SCR may be technologically feasible, but had some additional challenges. Because standby engines routinely operate only for scheduled maintenance and testing, the engines do not operate more than 15-30 minutes, and do operate at no or low load. Because of this the exhaust would not likely reach the temperature (260 °C to 540 °C) required for the catalyst to operate. To circumvent this problem, the engine would need to be operated with higher loads and in many cases for longer periods of time. This could be a challenge for most emergency standby applications as most businesses do not have load banks in house and would have to create a larger load on the engine to get the catalyst up to operational temperature.

Urea handling and maintenance is also an important consideration. Urea crystallization in the lines can cause damage to the SCR system and to the engine itself. Crystallization in the lines is more likely in emergency standby engines due to their periodic and low hours of usage. Urea also has a shelf life of approximately two years. This could increase the cost of operating a SCR for emergency standby engines since the low number of annual hours of operation experienced by most emergency standby engines could lead to urea expiration. The urea would then have to be drained and replaced, creating an extra maintenance step and an increased cost to the end user.

ARB staff determined that while, SCR systems may be technically feasible, there are significant operational hurdles to overcome before routine use of SCR on emergency standby engines is practical. This is because the majority of operating hours for emergency standby engines occur during short 15 to 30 minute maintenance and testing checks are at low engine loads. In most cases, the temperature needed for the SCR catalyst to function will not be reached during this operation and the SCR will not provide the expected NOx reductions.

The table below shows the technologically feasible alternatives identified as capable of reducing emissions beyond the levels determined to be "Achieved in Practice" as per Rule 202, §205.1.a.

VOC	No other technologically feasible option identified
NOx	Selective Catalytic Reduction
SOx	No other technologically feasible option identified
PM10	No other technologically feasible option identified
PM2.5	No other technologically feasible option identified
CO	No other technologically feasible option identified

All identified control technologies are considered achieved in practice.

Cost Effective Determination:

After identifying the technologically feasible control options, a cost analysis is performed to take into consideration economic impacts for all technologically feasible controls identified.

Maximum Cost per Ton of Air Pollutants Controlled

1. A control technology is considered to be cost-effective if the cost of controlling one ton of that air pollutant is less than the limits specified below (except coating operations):

<u>Pollutant</u>	<u>Maximum Cost (\$/ton)</u>
ROG	17,500
NO _x	24,500
PM ₁₀	11,400
SO _x	18,300
CO	TBD if BACT triggered

Cost Effectiveness Analysis Summary

SCR:

As shown in Attachment C, the cost effectiveness for the add on SCR system to control NOx to a 96% weight reduction was calculated to be **\$162,913.75/ton** for a 499 bhp engine and **\$129,580.57/ton** for a 1000 bhp engine (see attached Engine Cost Effectiveness Analysis). The following basic parameters were used in the analysis.

499 BHP Engine

NOx Control Level = 0.02356 lb/MMBtu (96% weight reduction)

NOx Baseline Level = 0.589 lb/MMBtu (160 ppmv @ 15% O2 per Subpart JJJJ)

Engine Rating = 499 BHP (4.8 MMBtu/hr)

Equipment Life = 20 years

Direct Cost = \$139,848.01

Direct Annual Cost = \$3,449.03 per year

Indirect Annual Cost = \$18,659.28 per year

Total Annual Cost = \$22,108.31 per year

NOx Removed = 0.14 tons per year

Cost of NOx Removal = \$162,913.75 per ton reduced

1,000 BHP Engine

NOx Control Level = 0.02356 lb/MMBtu (96% weight reduction)

NOx Baseline Level = 0.589 lb/MMBtu (160 ppmv @ 15% O2 per Subpart JJJJ)

Engine Rating = 1,000 BHP (4.8 MMBtu/hr)

Equipment Life = 20 years

Direct Cost = \$220,942.20

Direct Annual Cost = \$5,657.54 per year

Indirect Annual Cost = \$29,512.08 per year

Total Annual Cost = \$35,169.62 per year

NOx Removed = 0.27 tons per year

Cost of NOx Removal = \$129,580.57 per ton reduced

Therefore, the add-on SCR system is considered not cost effective for either engine size and is eliminated.

C. SELECTION OF BACT/T-BACT:

Based on the above analysis, BACT for VOC, NOx, SOx, PM10, and CO will remain at what is currently achieved in practice and BACT for PM2.5 will be set to be the same as for PM10.

Volatile hazardous air pollutants (VHAP) are the primary driver for health risks associated with gaseous fueled engines. VHAPs are emitted as VOC, and the same control technologies that control VOC also control VHAPs. Therefore, the BACT for VOC and T-BACT for VHAPs are the same.

Table 1: BACT FOR SPARK IGNITED I.C. ENGINES, STANDBY, GASEOUS-FUELED (EXCLUDING BIOGAS) <500 BHP		
Pollutant	Standard	Source
VOC	<u>Lean Burn</u> 1.0 g/bhp-hr	BAAQMD
	<u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines) ^(A)	SMAQMD
NOx	<u>Lean-Burn:</u> 1.0 g/bhp-hr	BAAQMD
	<u>Rich Burn:</u> 25 ppmvd @ 15% O ₂ OR 96% weight reduction (0.44 g/bhp-hr for naturally aspirated engines) (0.42 g/bhp-hr for turbocharged engines)	SDAPCD (Rule 69.4.1) & ARB
SOx	Natural gas or equivalent fuel	SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD
PM10	Natural gas or equivalent fuel	SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD
PM2.5	Natural gas or equivalent fuel	SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD
CO	2.0 g/bhp-hr	SCAQMD

(A) Control efficiency conversion to g/bhp-hr is based on uncontrolled emission factors from AP-42, Table 3.2-3 (7/00), and engine brake-specific fuel consumption (BSFC) from SBCAPCD *Piston IC Engine Technical Reference Document*, Table 6 (11/1/02).

Table 2: T-BACT FOR SPARK IGNITED I.C. ENGINES, STANDBY, GASEOUS-FUELED (EXCLUDING BIOGAS) <500 BHP		
Pollutant	Standard	Source
VHAP ^(A)	1.0 g/bhp-hr	BAAQMD

(A) A full list of the volatile hazardous air pollutants (VHAP) from natural gas combustion can be found in AP-42, Section 3.2 Natural Gas-fired Reciprocating Engines, Tables 3.2-1, 3.2-2, and 3.2-3.

Table 3: BACT FOR SPARK IGNITED I.C. ENGINES, STANDBY, GASEOUS-FUELED (EXCLUDING BIOGAS) ≥500 BHP		
Pollutant	Standard	Source
VOC	<u>Lean Burn</u> 0.6 g/bhp-hr	EPA, MD-0036
	<u>Rich Burn</u> 50% Control efficiency, 3-way catalyst with air-to-fuel ratio controller (0.29 g/bhp-hr for rich burn engines) ^(A)	SMAQMD
NOx	<u>Lean-Burn:</u> 0.5 g/bhp-hr	EPA (MI-0390)
	<u>Rich-Burn:</u> 25 ppmvd @ 15% O ₂ OR 96% weight reduction (0.44 g/bhp-hr for naturally aspirated engines) (0.42 g/bhp-hr for turbocharged engines)	SDAPCD (Rule 69.4.1) & ARB
SOx	Natural gas or equivalent fuel	SMAQMD, SCAQMD, SJVUAPCD, and BAAQMD
PM10	0.0099 lb/MMBtu	EPA (MD-0036)
PM2.5	0.0099 lb/MMBtu	EPA (MD-0036)
CO	1.5 g/p-hr	EPA (MD-0036)

Table 4: T-BACT FOR SPARK IGNITED I.C. ENGINES, STANDBY, GASEOUS-FUELED ≥500 BHP		
Pollutant	Standard	Source
VHAP ^(A)	0.6 g/bhp-hr	EPA (MD-0036)

(A) A full list of the volatile hazardous air pollutants (VHAP) from natural gas combustion can be found in AP-42, Section 3.2 Natural Gas-fired Reciprocating Engines, Tables 3.2-1, 3.2-2, and 3.2-3.

REVIEWED BY: _____ **DATE:** _____

APPROVED BY: _____ **DATE:** _____

Attachment A




Review of BACT Determinations published by EPA

List of BACT determinations published in EPA's RACT/BACT/LAER Clearinghouse (RBLC) for Natural Gas (includes propane & liquefied petroleum gas) I.C. Engines ≤ 500 BHP & > 500 BHP

RBLC#	Permit Date ^(A)	Process Code ^{(B), (C)}	Engine Burn Type	Rating	Pollutant	Standard	Case-By-Case Basis
LA-0256	12/06/2011	17.130	Not Listed	1,818 BHP	PM10	0.01 lb/hr	BACT-PSD, Operating Permit ^(D)
LA-0256	12/06/2011	17.130	Not Listed	1,818 BHP	PM2.5	0.01 lb/hr	BACT-PSD, Operating Permit ^(D)
LA-0256	12/06/2011	17.130	Not Listed	1,818 BHP	PM (TSP)	0.01 lb/hr	BACT-PSD, Operating Permit ^(D)
LA-0257	12/06/2011	17.130	Not Listed	2,012 BHP	CO	4.0 lb/bhp-r	BACT-PSD ^(E)
LA-0257	12/06/2011	17.130	Not Listed	2,012 BHP	NOx	2.0 g/bhp-hr	BACT-PSD ^(E)
LA-0257	12/06/2011	17.130	Not Listed	2,012 BHP	PM (TPM)	N/A	BACT-PSD
LA-0257	12/06/2011	17.130	Not Listed	2,012 BHP	VOC	1.0 g/bhp-r	BACT-PSD ^(E)
CA-1192	6/21/2011	17.130	Not Listed	860 BHP (550.0 KW)	CO	N/A	BACT-PSD ^(F)
CA-1192	6/21/2011	17.130	Not Listed	860 BHP (550.0 KW)	NOx	N/A	BACT-PSD ^(F)
CA-1192	6/21/2011	17.130	Not Listed	860 BHP (550.0 KW)	PM (TPM)	N/A	BACT-PSD ^(F)
CA-1192	6/21/2011	17.130	Not Listed	860 BHP (550.0 KW)	PM (PM10)	N/A	BACT-PSD ^(F)
MI-0390	10/14/2010	17.130	Not Listed	1818 BHP	NOx	0.5 g/bhp-hr	BACT-PSD, NSPS, NESHAP
LA-0232	6/24/2008	17.130	Not Listed	838 BHP	NOx	4.8 lb/hr	BACT-PSD, Operating Permit
LA-0232	6/24/2008	17.130	Not Listed	838 BHP	VOC	1.39 lb/hr	BACT-PSD, Operating Permit
MD-0036	3/10/2006	17.130	Not Listed	1,085 BHP (770KW)	CO	1.5 g/bhp-hr	BACT-PSD
MD-0036	3/10/2006	17.130	Not Listed	1,085 BHP (770KW)	NOx	2.0 g/bhp-hr	BACT-PSD
MD-0036	3/10/2006	17.130	Not Listed	1,085 BHP (770KW)	PM (FPM10)	0.0099 lb/MMBtu	BACT-PSD ^(G)

RBLC#	Permit Date ^(A)	Process Code ^{(B), (C)}	Engine Burn Type	Rating	Pollutant	Standard	Case-By-Case Basis
MD-0036	3/10/2006	17.130	Not Listed	1,085 BHP (770 KW)	VOC	0.6 g/hp-hr	LAER
IA-0102	2/1/2012	17.230	Not Listed	225 KW	VOC	0.66 lb/hr	BACT-PSD ^(H)
WA-0316	6/14/2006	17.230	Not Listed	450 KW	NOx	82 g/hr	BACT-PSD ^(I)
NV-0048	5/16/2006	17.230	Not Listed	771 BHP (575 KW)	CO	2.0 g/bhp-hr	Other Case-by-Case, SIP, Operating Permit
NV-0048	5/16/2006	17.230	Not Listed	771 BHP (575 KW)	NOx	21.5 g/bhp-hr	Other Case-by-Case, SIP, Operating Permit
NV-0048	5/16/2006	17.230	Not Listed	771 BHP (575 KW)	PM (FPM10)	0.0410 g/bhp-hr	Other Case-by-Case, SIP, Operating Permit
NV-0048	5/16/2006	17.230	Not Listed	771 BHP (575 KW)	SOx	0.0052 g/bhp-hr	Other Case-by-Case, SIP, Operating Permit
NV-0048	5/16/2006	17.230	Not Listed	771 BHP (575 KW)	VOC	0.23 g/bhp-hr	Other Case-by-Case, SIP, Operating Permit

- (A) Due to the large number of entries only determinations made (based on Permit Date) entered since 01/01/2005 are included in the above table.
- (B) Process Code 17.130 includes Large Internal Combustion Engines (> 500 BHP) fueled using natural gas (includes propane and liquid petroleum gas).
- (C) Process Code 17.230 includes Small Internal Combustion Engines (\leq 500 BHP) fueled using natural gas (includes propane and liquid petroleum gas).
- (D) BACT was determined to be use of natural gas fuel and good combustion practices. Emission limits for PM10, PM2.5, and PM (TSP) were determined to be <0.01 lb/hr and was established by Louisiana Department of Environmental Quality Permit [PSD-LA-754](#) for Westlake Vinyls Company, LP.
- (E) Emission Limits are based on [40 CFR Part 60 Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines](#). (NSPS, Subpart IIII)
- (F) The Ninth Circuit Court of Appeals issued a decision on 8/12/2014 that vacated the permit decision and remanded it to EPA. Therefore, this BACT determination has not yet been achieved in practice. Source: EPA Region IX, [Avenal Energy Product](#).
- (G) Emission limit for PM is based on AP-42 PM condensable emission factor for natural gas-fired reciprocating engines.
- (H) BACT was determined to be good combustion practices. Emission limit for VOC was determined to be 0.66 lb/hr and was established by Iowa Department of Natural Resources; Air Quality Bureau, Title V Permit [03-TV-025R2](#) (page 133) for Alcoa, Inc.
- (I) BACT was determined to be non-selective catalytic reduction. Emission limit for NOx was determined to be \leq 82 g/hr and was established by Washington State Department of Ecology; Air Quality Program, Permit [PSD-01-09 Amendment 6](#) for Northwest Pipeline Corporation

-  = Not enough information provided to determine if engine is used for standby purposes.
-  = Not applicable to this determination. Equipment has not yet been achieved in practice or is for a specific purpose outside of the scope of this determination.
-  = Selected as the most stringent BACT determination achieved in practice.

Attachment B

Review of BACT Determinations published by ARB

List of BACT determinations published in ARB's BACT Clearinghouse for ICE: Spark Ignition, Natural Gas & ICE: Emergency, Spark Ignition:

Capacity	Source	Date	Engine Burn Type	NOx	VOC	CO	PM10	SOx
528 BHP	MBUAPCD	10/13/2005	Rich Burn	0.07 g/bhp-hr ^(A)	N/A	N/A	N/A	N/A
93 BHP	SCAQMD	10/06/2000	Rich Burn	0.15 g/bhp-hr ^(B)	0.15 g/bhp-hr	0.6 g/bhp-hr	N/A	N/A
1334 BHP	SCAQMD	12/7/1999	Rich Burn	1.5 g/bhp-hr ^(B)	1.5 g/bhp-hr ^(B)	2.0 g/bhp-hr ^(B)	N/A	N/A
750 BHP	SCAQMD ^(C)	N/A	Rich Burn	0.15 g/bhp-hr ^(B)	0.15 g/bhp-hr ^(B)	0.6 g/bhp-hr ^(B)	N/A	N/A
310 BHP	SMAQMD ^(D)	10/22/2004	Rich Burn	2.13 g/bhp-hr ^(A)	0.0449 ^(A)	1.6 g/bhp-hr ^(A)	0.152 g/bhp-hr	0.002 g/bhp-hr

(A) Add-on control – 3-way catalytic converter,

(B) Add-on control – 3-way catalytic converter and air/fuel ratio controller

(C) SCAQMD is reconsidering the BACT requirement for future applications of this type. Source: [SCAQMD Application No. 359876](#)

(D) Emission limits are based on emissions for the specific engine and is not a standard for gaseous emergency standby engines

= Not enough information to determine if engine is for standby purposes

= Selected as the most stringent BACT determination achieved in practice.

Attachment C

Cost Effectiveness Calculations

ENGINE SCR COST EFFECTIVENESS CALCULATION

EPA AIR POLLUTION CONTROL COST MANUAL, Sixth Edition, EPA/452/B-02-001, January 2002

Section 4.2 - NOx Post-Combustion, Chapter 2 - Selective Catalytic Reduction

Cost Effectiveness = \$ 162,913.75 \$/ton

Equipment

Engine rating (499 bhp)	4.8	mmBTU/hr
Engine Operating hours	100	hours
Engine capacity factor	1	
SCR Operating Days	365	days
Total Capacity Factor	1	
Baseline Nox (160 PPM @ 15% O2 per Subpart JJJ)	0.589	lb/mmBTU
SCR Nox (96% weight reduction)	0.02356	lb/mmBTU
Ammonia Slip	10	ppm
Ammonia Stoichiometric Ratio	1.05	
Stored Ammonia Conc	29	%
Ammonia Storage days	90	days
Sulfur Content	0.005	%
Pressure drop for SCR Ductwork	3	inches W.G.
Pressure drop for each Catalyst Layer	1	inches W.G.
Temperature at SCR Inlet	650	degrees F
Cost year	1998	
Equipment Life	20	years
Annual interest Rate	7	%
Catalyst cost, Initial	240	\$/ft2
Catalyst cost, replacement	290	\$/ft2
Electrical Power cost	0.05	\$/KWh
Ammonia Cost	0.101	\$/lb
Catalyst Life	24000	hr
Catalyst Layers	2 full, 1 empty	

Engine Calculations

Q_B 4.8 mmBTU/hr

$Q_{\text{flue gas}}$	1710.371508	acfm
N_{NOx}	0.96	

SCR Reactor Calculations

Vol_{Catalyst}	14.47935815	ft ³
A_{Catalyst}	1.781636988	ft ²
A_{SCR}	2.048882536	ft ²
$l=w=$	1.431391818	ft
n_{layer}	3	
h_{layer}	3.708998943	
n_{total}	4	
h_{SCR}	51.83599577	ft

Reagent Calculations

m_{reagent}	1.098773675	lb/hr
m_{sol}	3.788874742	lb/hr
Q_{sol}	0.50615307	gph
Tank Volume	1093.290632	gal

Cost Estimation

Direct Costs

DC	\$	139,848.01
----	----	------------

Indirect Costs

General Facilities	\$	6,992.40
Engineering and home office fees	\$	13,984.80
Process Contingency	\$	6,992.40
Total Indirect Installation Costs	\$	27,969.60
Project Contingency	\$	25,172.64
Total Plant Cost	\$	192,990.25
Preproduction Cost	\$	3,859.80
Inventory Capital	\$	826.58
Total Capital Investment	\$	197,676.63

Direct Annual Costs

Maintenance Costs	\$	2,965.15	per yr
Power		2.04898176	KW
Annual Electricity	\$	10.24	per yr

Reagent Solution Cost	\$	38.27	per yr
-----------------------	----	-------	--------

Catalyst Replacement

FWF		0.311051666	
-----	--	-------------	--

Annual Catalyst Replacement	\$	435.37	per yr
-----------------------------	----	--------	--------

Total Variable Direct Cost	\$	483.88	per yr
----------------------------	----	--------	--------

Total Direct Annual Cost	\$	3,449.03	per yr
--------------------------	----	----------	--------

CRF		0.094392926	
-----	--	-------------	--

Indirect Annual Cost	\$	18,659.28	per yr
----------------------	----	-----------	--------

Total annual Cost	\$	22,108.31	per yr
-------------------	----	-----------	--------

Nox Removed		0.14	tons
-------------	--	------	------

Cost of Nox removal	\$	162,913.75	per ton
---------------------	----	------------	---------

ENGINE SCR COST EFFECTIVENESS CALCULATION

EPA AIR POLLUTION CONTROL COST MANUAL, Sixth Edition, EPA/452/B-02-001, January 2002

Section 4.2 - NOx Post-Combustion, Chapter 2 - Selective Catalytic Reduction

Cost Effectiveness = \$ 129,580.57 \$/ton

Equipment

Engine rating (1000 bhp)	9.6	mmBTU/hr
Engine Operating hours	100	hours
Engine capacity factor	1	
SCR Operating Days	365	days
Total Capacity Factor	1	
Baseline Nox (160 PPM @ 15% O2 per Subpart JJJ)	0.589	lb/mmBTU
SCR Nox (96% weight reduction)	0.02356	lb/mmBTU
Ammonia Slip	10	ppm
Ammonia Stoichiometric Ratio	1.05	
Stored Ammonia Conc	29	%
Ammonia Storage days	90	days
Sulfur Content	0.005	%
Pressure drop for SCR Ductwork	3	inches W.G.
Pressure drop for each Catalyst Layer	1	inches W.G.
Temperature at SCR Inlet	650	degrees F
Cost year	1998	
Equipment Life	20	years
Annual interest Rate	7	%
Catalyst cost, Initial	240	\$/ft2
Catalyst cost, replacement	290	\$/ft2
Electrical Power cost	0.05	\$/kWh
Ammonia Cost	0.101	\$/lb
Catalyst Life	24000	hr
Catalyst Layers	2 full, 1 empty	

Engine Calculations

Q_B 9.6 mmBTU/hr

$Q_{\text{flue gas}}$	3420.743017	acfm
N_{NOx}	0.96	

SCR Reactor Calculations

Vol_{Catalyst}	28.9587163	ft ³
A_{Catalyst}	3.563273976	ft ²
A_{SCR}	4.097765072	ft ²
$l=w=$	2.024293722	ft
n_{layer}	3	
h_{layer}	3.708998943	
n_{total}	4	
h_{SCR}	51.83599577	ft

Reagent Calculations

m_{reagent}	2.197547351	lb/hr
m_{sol}	7.577749485	lb/hr
Q_{sol}	1.012306141	gph
Tank Volume	2186.581265	gal

Cost Estimation

Direct Costs

DC	\$	220,942.20
----	----	------------

Indirect Costs

General Facilities	\$	11,047.11
Engineering and home office fees	\$	22,094.22
Process Contingency	\$	11,047.11
Total Indirect Installation Costs	\$	44,188.44
Project Contingency	\$	39,769.60
Total Plant Cost	\$	304,900.24
Preproduction Cost	\$	6,098.00
Inventory Capital	\$	1,653.16
Total Capital Investment	\$	312,651.41

Direct Annual Costs

Maintenance Costs	\$	4,689.77	per yr
Power		4.09796352	KW
Annual Electricity	\$	20.49	per yr

Reagent Solution Cost	\$	76.54	per yr
-----------------------	----	-------	--------

Catalyst Replacement

FWF		0.311051666	
-----	--	-------------	--

Annual Catalyst Replacement	\$	870.74	per yr
-----------------------------	----	--------	--------

Total Variable Direct Cost	\$	967.77	per yr
----------------------------	----	--------	--------

Total Direct Annual Cost	\$	5,657.54	per yr
--------------------------	----	----------	--------

CRF		0.094392926	
-----	--	-------------	--

Indirect Annual Cost	\$	29,512.08	per yr
----------------------	----	-----------	--------

Total annual Cost	\$	35,169.62	per yr
-------------------	----	-----------	--------

Nox Removed		0.27	tons
-------------	--	------	------

Cost of Nox removal	\$	129,580.57	per ton
---------------------	----	------------	---------