



Compliance Assistance Advisory

Advisory # 2023-01

Subject: GDF ISD Record Keeping

Date: January 2023

In-Station Diagnostics (ISD) Recordkeeping

Background

This advisory is to remind gasoline dispensing facility (GDF) owners and operators of the permit requirements for clearing ISD warning alarms. This reminder is being issued due to increased non-compliance with reporting log requirements. These requirements are listed in your permit.

Requirement

All permits require owners/operators to do the following:

Record all ISD warning alarm on your alarm logs. The log shall include the ISD alarm event, course of action taken, repairs made, and tests or procedures performed. This includes all alarms, not only alarms that are cleared by a contractor.

Compliance staff will continue to verify log entries of ISD alarms during inspections. Please be advised that non-compliance with reporting logs can result in substantial civil or criminal penalties.

More Information

Please contact District staff at sacvapor@airquality.org or 279-207-1122 if you have any questions about the information provided in this advisory.

ISD alarm logs can be found here:

www.AirQuality.org/StationarySources/Documents/ISDAlarmEventLog.pdf

Sac Metro Air District advisories are available online at:

www.AirQuality.org/businesses/compliance-with-permits-rules/compliance-advisories