

SMAQMD BACT CLEARINGHOUSE

ACTIVE

CATEGORY Type:

BOILER

BACT Category: Minor Source BACT

BACT Determination Number:	343	BACT Determination Date:	2/9/2024
Equipment Information			
Permit Number:	N/A -- Generic BACT Determination		
Equipment Description:	BOILER > 5 MMBTU		
Unit Size/Rating/Capacity:	> 20 MMBtu/hr, natural gas or LPG fired		
Equipment Location:			
BACT Determination Information			
District Contact: Jeff Quok Phone No.: (279) 207-1145 email: jquok@airquality.org			
ROCs	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
NOx	Standard:	2.5 ppm @ 3% O2 or 0.003 lb/MMBtu	
	Technology Description:		
	Basis:	Achieved in Practice	
SOx	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
PM10	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
PM2.5	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
CO	Standard:	50 ppm @ 3% O2 or 0.037 lb/MMBtu	
	Technology Description:		
	Basis:	Achieved in Practice	
LEAD	Standard:		
	Technology Description:		
	Basis:		
Comments: This is a generic BACT determination based on BACT determinations made, and published, by other air agencies in California and/or other States.			

SMAQMD BACT CLEARINGHOUSE

ACTIVE

CATEGORY Type:

BOILER

BACT Category: Minor Source BACT

BACT Determination Number:	344	BACT Determination Date:	2/9/2024
Equipment Information			
Permit Number: N/A -- Generic BACT Determination Equipment Description: RENTAL BOILER > 5 MMBTU Unit Size/Rating/Capacity: > 20 MMBtu/hr, Natural gas or LPG fired Equipment Location:			
BACT Determination Information			
District Contact: Jeff Quok Phone No.: (279) 207-1145 email: jquok@airquality.org			
ROCs	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
NOx	Standard:	5 ppm @ 3% O2 or 0.0062 lb/MMBtu	
	Technology Description:		
	Basis:	Achieved in Practice	
SOx	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
PM10	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
PM2.5	Standard:	PUC quality natural gas or propane with LPG backup	
	Technology Description:		
	Basis:	Achieved in Practice	
CO	Standard:	50 ppm @ 3% O2 or 0.037 lb/MMBtu	
	Technology Description:		
	Basis:	Achieved in Practice	
LEAD	Standard:		
	Technology Description:		
	Basis:		
Comments: This is a generic BACT determination based on BACT determinations made, and published, by other air agencies in California and/or other States.			

**BEST AVAILABLE CONTROL TECHNOLOGY DETERMINATION****DETERMINATION NOS.:** 343 & 344**DATE:** 2/9/2024**ENGINEER:** Jeffrey Quok**Category/General Equip Description:** Boiler/Heater – Natural Gas or LPG Fired**#343** – Boiler/Heater Natural Gas or LPG Fired,
> 20 MMBtu/hr**Equipment Specific Description:****#344** – Rental Boiler/Heater Natural Gas or LPG
Fired, > 20 MMBtu/hr**Equipment Size/Rating:**

Minor Source BACT

Previous BACT Det. No.:

N/A

These determinations will focus on both stationary and rental natural gas and LPG boilers/heaters, which include external combustion equipment used to produce hot water or steam and units which transfer heat from combustion gases to water or process streams. Heaters do not include any dryer in which the material being dried is in direct contact with the products of combustion, cement or lime kilns, glass melting furnaces, or smelters. Rental boilers are units that are rented out to provide facilities temporary support to increase capacity or to provide temporary support while boilers are under repair or replacement.

BACT/T-BACT ANALYSIS**A. ACHIEVED IN PRACTICE (Rule 202, §205.1a):**

The following control technologies are currently employed as BACT/T-BACT for boilers/heaters greater than 20 MMBtu/hr by the following air pollution control districts:

US EPA

BACT

Source: EPA RACT/BACT/LAER Clearinghouse (See Attachment A)

RBLC ID: OH-0387

For Natural Gas, 29.4 MMBtu/hr Boiler	
VOC	0.005 lb/MMBtu (Good combustion practices and use of natural gas)
NOx	0.011 lb/MMbtu (9 ppm @ 3% O ₂)
SOx	No standard
PM10	0.0005 lb/MMBtu (Good combustion practices and use of natural gas)
PM2.5	0.0004 lb/MMBtu (Good combustion practices and use of natural gas)
CO	0.037 lb/MMBtu (Good combustion practices and use of natural gas)

This BACT determination was found to be the most stringent Achieved in Practice BACT determination published in the EPA clearinghouse. See Attachment A for more information.

Note: The BACT emission limits for VOC, NOx, PM10, PM2.5, and CO are based on good combustion practices and the use of natural gas. Since these emission limits are not verified through testing, good combustion practices and use of natural gas will be considered BACT.

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

[40 CFR 60 Subpart Dc – Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units \(1/13/2007\)](#)

This regulation applies to steam generating units rated at between 10-100 MMBtu/hr. However, no standards within the subpart are applicable to units fired by natural gas or LPG only. Therefore, this NSPS is not applicable.

[40 CFR 60 Subpart Db – Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units \(1/13/2007\)](#)

This regulation applies to steam generating units rated at greater than 100 MMBtu/hr. However, no standards within the subpart are applicable to units fired by natural gas or LPG only. Therefore, this NSPS is not applicable.

[40 CFR Part 63, Subpart JJJJJJ – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers at Area Sources \(2/21/2011\)](#)

This rule applies if you own or operate a boiler combusting solid fossil fuels, biomass, or liquid fuels located at an area source, except for emergencies, gas curtailment or periodic testing. Boilers fired on natural gas or LPG as a primary fuel are not covered in this subpart. Since

this BACT is for natural gas and LPG fuels, this regulation does not apply.

[40 CFR Part 63, Subpart DDDDD – National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers for Major Sources \(2/21/2011\)](#) will be discussed here. This rule only applies to boilers located at a major source of HAPs. A major source is a facility that has a potential to emit 10 tons per year of any single air toxic or 25 tons per year of any combination of air toxics. This rule sets emission standards for Particulate Matter, Mercury, Hydrochloric acid, Carbon Monoxide, and Dioxins/Furans for all boilers that are not burning a fuel that qualifies as Gas 1 (i.e., natural gas). All boilers that combust fuels that qualify as Gas 1 or any other boiler \geq 10 MMBtu/hr will be required to perform an annual tune-up. Lastly, any existing boiler located at a major source must have a one-time energy assessment performed on the major source facility by qualified energy assessor. Since these BACTs are only for minor sources, this regulation does not apply.

California Air Resource Board (CARB)

BACT

Source: [ARB BACT Clearinghouse](#)
[CARB BACT Guidelines Search](#)
[App No. 562449 \(3-22-16\) SCAQMD](#)

For Natural gas, Watertube, 39.9 MMBtu/hr Boiler with SCR	
VOC	No standard
NOx	5 ppmvd corrected to 3% O ₂ with 15 minute averaging time.
SOx	No standard
PM10	No standard
PM2.5	No standard
CO	100 ppmvd corrected to 3% O ₂ with 15 minute averaging time.
Inorganic	For Selective Catalytic Reduction (SCR): 5 ppmvd NH ₃ slip corrected to 3% O ₂ with 60-minute averaging time.

Inorganic BACT standard for ammonia (NH₃) will be considered on a case-by-case basis as ammonia slip can differ depending on NOx emissions of the specific unit.

T-BACT

Source: [ARB BACT Clearinghouse](#)
[CARB BACT Guidelines Search](#)

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

None.

Sacramento Metropolitan AQMD

BACT

Source: [SMAQMD BACT Clearinghouse](#)

No BACT Determinations for this category in the Clearinghouse.

T-BACT

No T-BACT Determinations for this category in the Clearinghouse.

RULE REQUIREMENTS:

[Rule 411 – NOx from Boilers, Process Heaters, and Steam Generators](#) (8-23-2007)

For units with a rating of > 20 MMBtu/hr, emissions shall not exceed the following levels:

1. 9 ppmvd of NOx corrected to 3% O₂
2. 400 ppmvd of CO corrected to 3% O₂

South Coast AQMD

BACT

Source: [SCAQMD BACT Guidelines for Non-Major Polluting Facilities, page 13](#) (9/2/2022)

For natural gas or propane fired with a rating of ≥ 20 :	
VOC	No Standard
NOx	Compliance with SCAQMD Rules 1146 (2-1-2019) (see below)
SOx	Use of natural gas
PM10	Use of natural gas
PM2.5	No standard
CO	Firetube Boiler: 50 ppmvd corrected to 3% O ₂ Watertube Boiler: 100 ppmvd corrected to 3% O ₂

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

[Reg XI, Rule 1146 – Emissions of Oxides of Nitrogen from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters \(12-4-2020\)](#)

Requirements Table 1146-1

Category - Boiler Rating \geq 20 and < 75 MMBTU/hr (Group II Units)	NOx Limit
Group II Units (All others) (A)	5 ppmvd @ 3% O ₂ or 0.0062 lbs/10 ⁶ Btu

(A) Group II Units (All Others) includes any unit with a rated heat input capacity less than 75 million Btu per hour down to and including 20 million Btu per hour, excluding thermal fluid heaters and units operated at schools and universities. All other units would include LPG/propane fired.

All units rated greater than or equal to 5 MMBtu/hr must have CO emissions \leq 400 ppmvd @ 3% O₂.

San Joaquin Valley APCD

BACT

Source: [SJVUAPCD BACT Guideline 1.1.2 \(11/30/22\)](#)

For natural gas or propane fired boilers/steam generators with heat input rating greater than 20 MMBTU/hr:	
VOC	PUC quality natural gas or propane with LPG backup
NOx	2.5 ppm @ 3% O ₂ (0.003 lb/MMBtu)
SOx	PUC quality natural gas or propane with LPG backup
PM10	PUC quality natural gas or propane with LPG backup
PM2.5	No Standard
CO	50 ppm @ 3% O ₂ (0.037 lb/MMBtu)

After discussions with R.F. MacDonald Company, it was found that current SCR boiler rental fleets can only meet 5 ppm NOx at 3% O₂ (See Attachment B). Since no SCR rental boilers can currently meet the 2.5 ppm NOx standards, SJVAPCD's NOx standard will be considered not achieved in practice for rental boilers.

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

[Rule 4306 – Boilers, Steam Generators, and Process Heaters – Phase 3 \(12-17-2020\)](#)

Until 12/31/23

Type (Gaseous Fuel Fired)	NOx Limit ppmvd @ 3% O ₂	CO Limit ppmvd @ 3% O ₂
Units with a rated heat input greater than 20.0 MMBtu/hr except categories oilfield steam generators, refinery units, load following units, and units limited to an annual heat input of 9 billion Btu/year to 30 billion Btu/year	9 or 0.011 lb/MMBtu	400
Units limited to an annual heat input of 9 billion Btu/year to 30 billion Btu/year	30 or 0.036 lb/MMBtu	400

After 12/31/23

Type (Gaseous Fuel Fired)	NOx Limit ppmvd @ 3% O ₂	CO Limit ppmvd @ 3% O ₂
Units with a total rated heat input > 20.0 MMBtu/hr and ≤ 75 MMBtu/hr	7 or 0.0085 lb/MMBtu	400

San Diego County APCD

BACT

Source: [NSR Requirements for BACT, page 3-5 and 3-6](#)

For boiler with a rating of < 50 MMBTU/hr :	
VOC	Natural gas or LPG fuel
NOx	9 ppm @ 3% O ₂ , natural gas or LPG
SOx	Natural gas or LPG fuel
PM10	Natural gas or LPG fuel
PM2.5	Natural gas or LPG fuel
CO	No Standard

For boiler with a rating of 50 to < 250 MMBTU/hr :	
VOC	Natural gas or LPG fuel
NOx	9 ppm @ 3% O ₂ , natural gas or LPG (Achieved in Practice) 5 ppm @ 3% O ₂ , natural gas or LPG (Technologically feasible)
SOx	Natural gas or LPG fuel
PM10	Natural gas or LPG fuel
PM2.5	Natural gas or LPG fuel
CO	No Standard

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

[Regulation 4, Rule 69.2 – Industrial and Commercial Boilers, Process Heaters and Steam Generators \(9-27-1994\)](#)

This rule applies to any unit with a heat input rating of 5 MMBtu/hr or more.

Equipment Type	Fuel	Heat Input Rating (Btu per hour)	Concentration of NOx (ppmv at 3% O₂)	Concentration of CO (ppmv at 3% O₂)
New Unit	Gaseous Fuel	Greater than or equal to 5 MMBtu/hr	30	400

Bay Area AQMD

BACT

Source: [BAAQMD BACT Workbook](#)

<u>BACT Guideline 17.1.1 (8/4/2010)</u> For boiler with a rating of 5 to < 33.5 MMBTU/hr :	
VOC	Good Combustion Practice
NOx	Low NOx burners and Flue Gas Recirculation
SOx	Natural gas with ≤ 100 ppmvd total reduced sulfur
PM10	Natural gas
PM2.5	Natural gas
CO	Firetube Boiler: 50 ppmvd corrected to 3% O ₂ Watertube Boiler: 100 ppmvd corrected to 3% O ₂

<u>BACT Guideline 17.2.1 (8/4/2010)</u>	
For boiler with a rating of 33.5 to < 50 MMBTU/hr :	
VOC	Good Combustion Practice
NOx	Low NOx burners and Flue Gas Recirculation
SOx	Natural gas with ≤ 100 ppmv total reduced sulfur
PM10	Natural gas
PM2.5	Natural gas
CO	100 ppmvd corrected to 3% O ₂

<u>BACT Guideline 17.3.1 (8/4/2010)</u>	
For boiler with a rating of ≥ 50 MMBTU/hr :	
VOC	Good Combustion Practice
NOx	40 ppm NOx @ 3% O ₂ , Ultra Low NOx burners and Flue Gas Recirculation
SOx	Natural gas with ≤ 100 ppmv total reduced sulfur
PM10	Natural gas
PM2.5	Natural gas
CO	50 ppmvd corrected to 3% O ₂

T-BACT

There are no T-BACT standards published in the clearinghouse for this category.

RULE REQUIREMENTS:

[Regulation 9, Rule 7 – Nitrogen Oxides and Carbon Monoxide from Industrial, Institutional, and Commercial Boilers, Steam Generators, and Process Heaters \(5-4-2011\)](#)

For gaseous, except landfill or digester gas units with a rating of 20 MMBtu/hr and less than 75 MMBtu/hr:

1. NOx limit of 9 ppmvd corrected to 3% O₂
2. CO limit of 400 ppmvd corrected to 3% O₂

Summary of Achieved in Practice Control Technologies

The following control technologies have been identified and are ranked based on stringency:

SUMMARY OF ACHIEVED IN PRACTICE CONTROL TECHNOLOGIES	
VOC	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Good combustion practice and use of natural gas – [EPA, SMAQMD, BAAQMD] 3. Natural gas or LPG fuel – [SDAPCD] 4. No standard – [ARB, SCAQMD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Good combustion practice and use of natural gas – [EPA, SMAQMD, BAAQMD] 3. Natural gas or LPG fuel – [SDAPCD] 4. No standard – [ARB, SCAQMD]
NOx	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. 2.5 ppm @ 3% O₂ (0.003 lb/MMBtu) – [SJVAPCD] 2. 5 ppmvd @ 3% O₂ or 0.0062 lbs/MMBtu [SCAQMD] 3. 9 ppmvd corrected to 3% O₂ – [EPA, SMAQMD, SDAPCD, BAAQMD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. 5 ppmvd @ 3% O₂ or 0.0062 lbs/MMBtu [SCAQMD] 2. 9 ppmvd corrected to 3% O₂ – [SMAQMD, SDAPCD, BAAQMD]
SOx	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Natural gas with ≤ 100 ppmvd total reduced sulfur – [BAAQMD] 3. Use of natural gas – [SCAQMD] 4. Natural gas or LPG fuel – [SDAPCD] 5. No standard – [EPA, CARB, SMAQMD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Natural gas with ≤ 100 ppmvd total reduced sulfur – [BAAQMD] 3. Use of natural gas – [SCAQMD] 4. Natural gas or LPG fuel – [SDAPCD] 5. No standard – [EPA, CARB, SMAQMD]
PM10	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Good combustion practice and use of natural gas – [EPA] 3. Use of natural gas – [SCAQMD, BAAQMD] 4. Natural gas or LPG fuel – [SDAPCD] 5. No standard – [CARB, SMAQMD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 2. Good combustion practice and use of natural gas – [EPA] 3. Use of natural gas – [SCAQMD, BAAQMD] 4. Natural gas or LPG fuel – [SDAPCD] 5. No standard – [CARB, SMAQMD]

SUMMARY OF ACHIEVED IN PRACTICE CONTROL TECHNOLOGIES	
PM2.5	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. Good combustion practice and use of natural gas – [EPA, SMAQMD] 2. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 3. Use of natural gas – [SCAQMD] 4. Natural gas or LPG fuel – [SDAPCD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. Good combustion practice and use of natural gas – [EPA, SMAQMD] 2. PUC quality natural gas or propane with LPG backup – [SJVAPCD] 3. Use of natural gas – [SCAQMD] 4. Natural gas or LPG fuel – [SDAPCD]
CO	<p><u>For Stationary Boilers</u></p> <ol style="list-style-type: none"> 1. 50 ppm @ 3% O₂ (0.037 lb/MMBtu) – [SJVAPCD, BAAQMD] 2. Firetube Boilers: 50 ppmvd corrected to 3% O₂, and Watertube Boilers: 100 ppmvd corrected to 3% O₂ – [SCAQMD, BAAQMD] 3. Good combustion practices and use of natural gas – [EPA] 4. No standard – [SMAQMD, SDAPCD] <p><u>For Rental Boilers</u></p> <ol style="list-style-type: none"> 1. 50 ppm @ 3% O₂ (0.037 lb/MMBtu) – [SJVAPCD, BAAQMD] 2. Firetube Boilers: 50 ppmvd corrected to 3% O₂, and Watertube Boilers: 100 ppmvd corrected to 3% O₂ – [SCAQMD, BAAQMD] 3. Good combustion practices and use of natural gas – [EPA] 4. No standard – [SMAQMD, SDAPCD]

The following control technologies have been identified as the most stringent, achieved in practice control technologies:

BEST CONTROL TECHNOLOGIES ACHIEVED		
Pollutant	Standard	Source
VOC	<p><u>For Stationary Boilers</u></p> <p>PUC quality natural gas or propane with LPG backup</p> <p><u>For Rental Boilers</u></p> <p>PUC quality natural gas or propane with LPG backup</p>	SJVAPCD
NO _x	<p><u>For Stationary Boilers</u></p> <p>2.5 ppm @ 3% O₂ or 0.003 lb/MMBtu</p> <p><u>For Rental Boilers</u></p> <p>5 ppmvd @ 3% O₂ or 0.0062 lbs/MMBtu</p>	<p>SJVAPCD</p> <p>SCAQMD</p>
SO _x	<p><u>For Stationary Boilers</u></p> <p>PUC quality natural gas or propane with LPG backup</p> <p><u>For Rental Boilers</u></p> <p>PUC quality natural gas or propane with LPG backup</p>	SJVAPCD

BEST CONTROL TECHNOLOGIES ACHIEVED		
Pollutant	Standard	Source
PM10	<u>For Stationary Boilers</u> PUC quality natural gas or propane with LPG backup <u>For Rental Boilers</u> PUC quality natural gas or propane with LPG backup	SJVAPCD
PM2.5	<u>For Stationary Boilers</u> PUC quality natural gas or propane with LPG backup <u>For Rental Boilers</u> PUC quality natural gas or propane with LPG backup	SJVAPCD
CO	<u>For Stationary Boilers</u> 50 ppm @ 3% O ₂ or 0.037 lb/MMBtu <u>For Rental Boilers</u> 50 ppm @ 3% O ₂ or 0.037 lb/MMBtu	SJVAPCD, BAAQMD

B. TECHNOLOGICALLY FEASIBLE AND COST EFFECTIVE (Rule 202, §205.1.b.):

Technologically Feasible Alternatives:

Any alternative basic equipment, fuel, process, emission control device or technique, singly or in combination, determined to be technologically feasible by the Air Pollution Control Officer.

The table below shows the technologically feasible alternatives identified as capable of reducing emissions beyond the levels determined to be “Achieved in Practice” as per Rule 202, §205.1.a.

Pollutant	Technologically Feasible Alternative
VOC	No other technologically feasible option identified
NOx	<u>Stationary Boilers</u> Selective Catalytic Reduction (SCR) – [BAAQMD, SDAPCD] <u>Rental Boilers</u> SCR for Rental Boilers with 2.5 ppm NOx emissions – [SJVACPD]
SOx	No other technologically feasible option identified
PM10	No other technologically feasible option identified
PM2.5	No other technologically feasible option identified
CO	No other technologically feasible option identified

BAAQMD and SDAPCD both list SCR as a technologically feasible alternative. However, SJVAPCD's BACT Guideline 1.1.2 standard of 2.5 ppm NOx is based on using SCR control technology. Therefore, no cost effectiveness determination will be performed on SCR for stationary boilers. A cost effectiveness analysis was performed on rental boilers for SCR that

can meet 2.5 ppm NO_x emissions.

Cost Effective Determination:

After identifying the technologically feasible control options, a cost analysis is performed to take into consideration economic impacts for all technologically feasible controls identified.

Maximum Cost per Ton of Air Pollutants Controlled

1. A control technology is considered to be cost-effective if the cost of controlling one ton of that air pollutant is less than the limits specified below:

<u>Pollutant</u>	<u>Maximum Cost (\$/ton) (Amended 9/5/23)</u>
VOC	25,300
NO _x	35,300
PM10	11,400
SO _x	18,300
CO	300

Cost Effectiveness Analysis Summary

This BACT determination will perform a cost effectiveness analysis in accordance with the updated EPA OAQPS Air Pollution Control Cost Manual. The interest rate was based on the previous 6-month average interest rate on United States Treasury Securities (based on the life of the equipment) and addition of two percentage points and rounding up to the next higher integer rate.

NO_x:

SCR System:

A cost effectiveness analysis was done to determine if an SCR system (with 2.5 ppm NO_x @ 3% O₂ emissions) could be considered cost effective to control the NO_x from a rental boiler and is calculated in Appendix A of this document. The baseline emissions are based on 9 ppm NO_x @ 3% O₂ from SMAQMD Rule 411 standards. Emissions were calculated based on 24 hours per day, 365 days per year, and both a 20 and 100 MMBtu/hr boiler. For a rental boiler, it is assumed that the equipment life is 2 years.

For a 100 MMBtu/hr boiler

The total annualized cost for the SCR system is estimated to be \$877,054. The total NO_x controlled would be 3.46 tons/year at 2.5 ppmv. The analysis shows the cost effectiveness calculation to be \$253,469 per ton of NO_x reduced. Since the District's cost effectiveness threshold for NO_x is \$35,300 per ton, the addition of the SCR would not be considered cost effective.

Total Annualized Cost of SCR	Quantity of NO _x Controlled (TPY)	Cost of SCR per ton removed	SMAQMD cost effective threshold for NO _x	Cost effective
\$877,054	3.46 @ 2.5 ppmv	\$253,469 @ 2.5 ppmv of NO _x	\$35,300	No

For a 20 MMBtu/hr boiler

The total annualized cost for the SCR system is estimated to be \$292,034. The total NOx controlled would be 0.69 tons/year at 2.5 ppmv. The analysis shows the cost effectiveness calculation to be \$421,991 per ton of NOx reduced. Since the District's cost effectiveness threshold for NOx is \$35,300 per ton, the addition of the SCR would not be considered cost effective.

Total Annualized Cost of SCR	Quantity of NOx Controlled (TPY)	Cost of SCR per ton removed	SMAQMD cost effective threshold for NOx	Cost effective
\$292,034	0.69 @ 2.5 ppmv	\$421,991 @ 2.5 ppmv of NOx	\$35,300	No

Therefore, SCR is not cost effective for rental boilers at 2.5 ppm NOx.

C. SELECTION OF BACT:

Based on the above analysis, BACT for VOC, NOx, SOx, PM10, and CO will remain at what is currently achieved in practice and BACT for PM2.5 will be set to be the same as for PM10.

BACT #343 for Boiler/heater natural gas or LPG fired > 20 MMBtu/hr		
Pollutant	Standard	Source
VOC	PUC quality natural gas or propane with LPG backup	SJVUAPCD
NOx	2.5 ppm @ 3% O ₂ or 0.003 lb/MMBtu	SJVUAPCD
SOx	PUC quality natural gas or propane with LPG backup	SJVUAPCD
PM10	PUC quality natural gas or propane with LPG backup	SJVUAPCD
PM2.5	PUC quality natural gas or propane with LPG backup	SJVUAPCD
CO	50 ppm @ 3% O ₂ or 0.037 lb/MMBtu	SJVUAPCD, BAAQMD

BACT #344 for Rental Boiler/heater natural gas or LPG fired > 20 MMBtu/hr		
Pollutant	Standard	Source
VOC	PUC quality natural gas or propane with LPG backup	SJVUAPCD
NOx	5 ppm @ 3% O ₂ or 0.0062 lb/MMBtu	SCAQMD
SOx	PUC quality natural gas or propane with LPG backup	SJVUAPCD
PM10	PUC quality natural gas or propane with LPG backup	SJVUAPCD
PM2.5	PUC quality natural gas or propane with LPG backup	SJVUAPCD
CO	50 ppm @ 3% O ₂ or 0.037 lb/MMBtu	SJVUAPCD, BAAQMD

APPROVED BY: Brian F Krebs DATE: 02-09-2024

Attachment A

Review of BACT Determinations published by EPA

List of BACT determinations published in EPA's RACT/BACT/LAER Clearinghouse (RBLC) for Commercial/Institutional-Sized Boilers/Furnaces < 100 Million BTU/H - Natural Gas (includes propane & liquefied petroleum gas) (Process Code 13.310):

Boilers/Heaters > 20 MMBTU/hr							
RBLC#	Permit Date ^(A)	Rating	Fuel	Pollutant	Standard	Control Technology	Case-By-Case Basis
OH-0387	9/20/2022	29.4 MMBTU/hr	Natural gas	NOx	0.011 lb/MMbtu (9 ppm @ 3% O ₂)	Low NOx burner	BACT-PSD
				CO	0.037 lb/MMbtu	Good Combustion Practices	BACT-PSD
				PM10	0.0005 lb/MMbtu	Good Combustion Practices	BACT-PSD
				PM2.5	0.0004 lb/MMbtu	Good Combustion Practices	BACT-PSD
				VOC	0.005 lb/MMbtu	Good Combustion Practices	BACT-PSD
MI-0451	6/23/2022	61.5 MMBTU/hr	Natural gas	NOx	0.04 lb/MMbtu	Low NOx burner	BACT-PSD
				CO	0.08 lb/MMbtu	Good Combustion Practices	BACT-PSD
				PM10	0.46 lb/hr	Good Combustion Practices	BACT-PSD
				PM2.5	0.46 lb/hr	Good Combustion Practices	BACT-PSD
				VOC	0.004 lb/MMbtu	Good Combustion Practices	BACT-PSD
				SOx	0.6 gr/scf	Good Combustion Practices, pipeline quality natural gas	BACT-PSD

(A) Due to the large number of entries only determinations made (based on Permit Date) entered since 01/01/2013 are included in the above table.

 = Selected as the most stringent BACT determination achieved in practice.

Attachment B

Review of BACT Determinations published by CARB

List of BACT determinations published in CARB's BACT Clearinghouse for boilers ≥ 20 MMBtu/hr to 100 MMBtu/hr:

Capacity MMBtu/hr	Source	Date	Type	NOx ppmv @ 3% O ₂	CO ppmv @ 3% O ₂	VOC lbs/MMBtu	Filterable PM10 lbs/MMBtu	SO ₂ lbs/MMBtu	Inorganic
26.50	SANTA BARBARA COUNTY APCD	1/3/06	Not Specified	14	27	7 ppm or 0.003 lb/MMBtu	NA	NA	
24.9	SANTA BARBARA COUNTY APCD	5/16/06	Not Specified	9	50	NA	NA	NA	
25.0	SANTA BARBARA COUNTY APCD	1/24/12	Not Specified	7	50	12 ppm or 0.0054 lb/MMBtu	NA	NA	
28.8	SOUTH COAST AQMD	6/7/21	Portable water tube	9	50	NA	NA	NA	
39.9	SOUTH COAST AQMD	3/22/16	Water tube with SCR	5	100	NA	NA	NA	5 ppmvd @ 3% O ₂ NH ₃ slip

 = Selected as the most stringent BACT determination achieved in practice

Attachment C

R.F. MacDonald Rental Boiler Email

Jeffrey Quok

Subject: RE: R.F. MacDonald Co. - Sacramento Rendering Permit

From: Anthony Marino <Anthony.Marino@RFMacDonald.com>

Sent: Thursday, August 17, 2023 8:48 AM

To: Jeffrey Quok <JQuok@airquality.org>; Keith Clark <Keith.Clark@RFMacDonald.com>; Salvador Rodriguez <Salvador.Rodriguez@RFMacDonald.com>; Anthony Feliz <Anthony.Feliz@RFMacDonald.com>

Cc: Ali Othman <AOthman@airquality.org>; Tony Dalri <TDalri@airquality.org>; Angela Thompson <AThompson@airquality.org>; Brian Krebs <BKrebs@airquality.org>

Subject: RE: R.F. MacDonald Co. - Sacramento Rendering Permit

***** THIS EMAIL ORIGINATED OUTSIDE AIRQUALITY.ORG *****

The system has an SCR system installed with it. The SCR system can us down to around 5PPM. No other technology is available on rental systems to get us down to below 2.5PPM that would be guaranteed. Not yet, atleast.

See attached spec sheet SCR-WT for reference.

Please advise as we need to setup source testing and Blue Sky needs direction for the ST plan.

Thanks,

Anthony Marino
R.F.MacDonald Co.
1016 North Market Blvrd
Sacramento, CA 95834
209.747.1817 cell
916.696.6758 Sacramento Office
anthony.marino@RFMacDonald.com

Attachment D

SCR Rental Boiler Cost Effectiveness Analysis

SCR COST EFFECTIVENESS CALCULATION

EPA AIR POLLUTION CONTROL COST MANUAL, Sixth Edition, EPA/452/B-02-001, January 2002

Section 4.2 - NOx Post-Combustion, Chapter 2 - Selective Catalytic Reduction

Cost Effectiveness = \$ 253,469.15 \$/ton

Equipment

Boiler rating	100 mmBTU/hr
Boiler Operating hours	8760 hours
Boiler capacity factor	1
SCR Operating Days	365 days
Total Capacity Factor	1
Baseline NOx (9 ppm)	1.09E-02 lb/mmBTU
SCR NOx (2.5 ppm)	3.00E-03 lb/mmBTU
Ammonia Slip	10 ppm
Ammonia Stoichiometric Ratio	1.05
Stored Ammonia Conc	29 %
Ammonia Storage days	90 days
Sulfur Content	0.005 %
Pressure drop for SCR Ductwork	3 inches W.G.
Pressure drop for each Catalyst Layer	1 inch W.G.
Temperature at SCR Inlet	500 degrees F
Cost year	1998
Equipment Life	2 years
Annual interest Rate	6 %
Catalyst cost, Initial	240 \$/ft ²
Catalyst cost, replacement	290 \$/ft ²
Electrical Power cost	0.05 \$/KWh
Ammonia Cost	0.101 \$/lb
Catalyst Life	24000 hr
Catalyst Layers	2 full, 1 empty

Boiler Calculations

Q_g	100 mmBTU/hr
$Q_{\text{flue gas}}$	30817.50466 acfm
N_{NOx}	7.25E-01

SCR Reactor Calculations

Vol_{Catalyst}	4.07E+02 ft ³
A_{Catalyst}	32.10156735 ft ²
A_{SCR}	36.91680245 ft ²
$l=w$	6.075919885 ft
n_{layer}	4
h_{layer}	4.168837172
n_{total}	5
h_{SCR}	64.84418586 ft

Reagent Calculations

m_{reagent}	0.423621713 lb/hr
m_{sol}	1.460764526 lb/hr
Q_{sol}	0.19514249 gph
Tank Volume	421.5077777 gal

Cost Estimation

Direct Costs

DC	\$ 1,074,807.36
----	-----------------

Indirect Costs

General Facilities	\$	53,740.37
Engineering and home office fees	\$	107,480.74
Process Contingency	\$	53,740.37
Total Indirect Installation Costs	\$	214,961.47
Project Contingency	\$	193,465.32
Total Plant Cost	\$	1,483,234.16
Preproduction Cost	\$	29,664.68
Inventory Capital	\$	318.68
Total Capital Investment	\$	1,513,217.52

Direct Annual Costs

Maintenance Costs	\$	22,698.26	per yr
Power		42.08295	KW
Annual Electricity	\$	18,432.33	per yr
Reagent Solution Cost	\$	1,292.43	per yr

Catalyst Replacement

FWF		0.314109813
Annual Catalyst Replacement	\$	9,266.29 per yr
Total Variable Direct Cost	\$	28,991.04 per yr
Total Direct Annual Cost	\$	51,689.31 per yr
CRF		0.545436893
Indirect Annual Cost	\$	825,364.66 per yr
Total annual Cost	\$	877,053.97 per yr

NOx Removed	3.46	tons per year
--------------------	-------------	----------------------

Cost of NOx controlled per ton removal	\$ 253,469.15	per ton
---	----------------------	----------------

NOx emission factor without SCR (Based on 9 ppm NOx @ 3% O2)	10.9	NOx lb/MMft3
NOx emission factor with SCR (Based on 2.5 ppm NOx @ 3% O2)	3	NOx lb/MMft3
NOx emissions without SCR (Based on 9 ppm NOx @ 3% O2)	9548.40	lbs
NOx emissions with SCR (Based on 2.5 ppm NOx @ 3% O2)	2628.00	lbs
NOx emissions controlled with SCR	6920.40	lbs

SCR COST EFFECTIVENESS CALCULATION

EPA AIR POLLUTION CONTROL COST MANUAL, Sixth Edition, EPA/452/B-02-001, January 2002

Section 4.2 - NO_x Post-Combustion, Chapter 2 - Selective Catalytic Reduction**Cost Effectiveness = \$ 421,990.77 \$/ton****Equipment**

Boiler rating	20 mmBTU/hr
Boiler Operating hours	8760 hours
Boiler capacity factor	1
SCR Operating Days	365 days
Total Capacity Factor	1
Baseline NO _x (9 ppm)	1.09E-02 lb/mmBTU
SCR NO _x (2.5 ppm)	3.00E-03 lb/mmBTU
Ammonia Slip	10 ppm
Ammonia Stoichiometric Ratio	1.05
Stored Ammonia Conc	29 %
Ammonia Storage days	90 days
Sulfur Content	0.005 %
Pressure drop for SCR Ductwork	3 inches W.G.
Pressure drop for each Catalyst Layer	1 inch W.G.
Temperature at SCR Inlet	500 degrees F
Cost year	1998
Equipment Life	2 years
Annual interest Rate	6 %
Catalyst cost, Initial	240 \$/ft ²
Catalyst cost, replacement	290 \$/ft ²
Electrical Power cost	0.05 \$/KWh
Ammonia Cost	0.101 \$/lb
Catalyst Life	24000 hr
Catalyst Layers	2 full, 1 empty

Boiler Calculations

Q _g	20 mmBTU/hr
Q _{flue gas}	6163.500931 acfm
N _{NO_x}	7.25E-01

SCR Reactor Calculations

Vol _{Catalyst}	8.14E+01 ft ³
A _{Catalyst}	6.42031347 ft ²
A _{SCR}	7.38336049 ft ²
l=w=	2.717233978 ft
n _{layer}	4
h _{layer}	4.168837172
n _{total}	5
h _{SCR}	64.84418586 ft

Reagent Calculations

m _{reagent}	0.084724343 lb/hr
m _{sol}	0.292152905 lb/hr
Q _{sol}	0.039028498 gph
Tank Volume	84.30155554 gal

Cost Estimation**Direct Costs**

DC	\$ 362,797.69
----	---------------

Indirect Costs

General Facilities	\$	18,139.88
Engineering and home office fees	\$	36,279.77
Process Contingency	\$	18,139.88
Total Indirect Installation Costs	\$	72,559.54
Project Contingency	\$	65,303.58
Total Plant Cost	\$	500,660.81
Preproduction Cost	\$	10,013.22
Inventory Capital	\$	63.74
Total Capital Investment	\$	510,737.76

Direct Annual Costs

Maintenance Costs	\$	7,661.07	per yr
Power		8.41659	KW
Annual Electricity	\$	3,686.47	per yr
Reagent Solution Cost	\$	258.49	per yr

Catalyst Replacement

FWF		0.314109813
Annual Catalyst Replacement	\$	1,853.26 per yr
Total Variable Direct Cost	\$	5,798.21 per yr
Total Direct Annual Cost	\$	13,459.28 per yr

CRF		0.545436893	
Indirect Annual Cost	\$	278,575.22	per yr
Total annual Cost	\$	292,034.49	per yr

NOx Removed 0.69 tons per year

Cost of NOx controlled per ton removal \$ 421,990.77 per ton

NOx emission factor without SCR (Based on 9 ppm NOx @ 3% O2)	10.9	NOx lb/MMft3
NOx emission factor with SCR (Based on 2.5 ppm NOx @ 3% O2)	3	NOx lb/MMft3
NOx emissions without SCR (Based on 9 ppm NOx @ 3% O2)	1909.68	lbs
NOx emissions with SCR (Based on 2.5 ppm NOx @ 3% O2)	525.60	lbs
NOx emissions controlled with SCR	1384.08	lbs